

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
OREGON COAST HOSPITALITY
ECONOLODGE GARIBALDI
227 GARIBALDI AVE
GARIBALDI, OR 97118

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910200A Area: 30
Units: 22
County: 29

ECONOLODGE GARIBALDI
4801 N INTERSTATE AVE
PORTLAND, OR 97217

Phone: (503) 322-2552 x
Inspector: Jaime Craig

Start Date/Time: 9/16/2016 at 11:01:26 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

PERSON IN CHARGE EASILY FOUND
21 RENTABLE ROOMS
CHECKED ROOMS 206, 208
PET FRIENDLY (DOG) ALL SHEETS STRIPPED AFTER PET VISITS
BED LINENS CLEAN/MATTRESS PAD COVERS
SMOKE DETECTORS IN WORKING ORDER
FIRE EXTINGUISHERS SERVICE JULY 2016
BATHROOMS CLEAN AND STOCKED
**BATHROOM FAN IN 208 NOT WORKING
MICROWAVE AND FRIDGE CLEAN/WORKING
NO EVIDENCE OF INSECTS OR RODENTS
GARBAGE SERVICE TWICE A WEEK THROUGH FALL. GARBAGE AREA-GOOD
HANDRAILS ON STAIRWAYS-GOOD
LAUNDRY ROOM:
SHELVES WALLS SEALED
LIGHT BULBS COVERED
CHEMICAL STORED AWAY FROM CLEAN LINENS
DIRTY AND CLEAN LAUNDRY SEPARATE
**RECOMMEND GETTING SCREEN FOR LAUNDRY ROOM DOORS THAT OPEN TO OUTSIDE FOR VECTOR CONTROL.

Establishment: 2910200A
Inspection Type: ANNUAL

Page 2 of 9
Start Date/Time: 9/16/2016 at 11:01:26

Comments:

Site Report Generated: 6/23/2017 9:10:21 AM

Person In Charge

Inspection By: Jaime Craig

Page 2

Establishment: 2910200A
Inspection Type: ANNUAL

Page 3 of 9
Start Date/Time: 8/31/2015 at 3:22:12

Historical 8/31/2015

HOTEL/MOTEL INSPECTION REPORT

Page 3 of 9

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
OREGON COAST HOSPITALITY
ECONOLOGDE GARIBALDI
227 GARIBALDI AVE
GARIBALDI, OR 97118

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910200A Area: 30
Units: 22
County: 29

ECONOLOGDE GARIBALDI
4801 N INTERSTATE AVE
PORTLAND, OR 97217

Phone: (503) 322-2552 x
Inspector: Mason Lyman

Start Date/Time: 8/31/2015 at 3:22:12 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

ANNUAL INSPECTION OF FACILITY-

21 ROOMS TOTAL-
CHECKED ROOMS #104, 107.

ICE MACHINE CLEAN
SHEETS CLEAN, NO DEBRIS
MATTRESS PADS PROVIDED
FIRE ALARMS WORKING
FIRE EXT. WITHIN 75 FEET OF ROOMS.
SCREENS ON WINDOWS
FRIDGES COLD
MICROWAVES CLEAN
HOT WATER PRESENT IN ROOMS.
LAUNDRY ROOM CLEAN
GOOD SEPARATION BETWEEN DIRTY AND CLEAN LINENS
TOXIC SPRAY BOTTLES LABELED/ STORED WELL
SURFACES CLEAN AND SMOOTH

Establishment: 2910200A

Page 4 of 9

Inspection Type: ANNUAL

Start Date/Time: 8/31/2015 at 3:22:12

**NO VENTILATION SOURCE WITHIN ROOMS 104, AND 107, BUT VENT IN ROOM 103. STAFF PLEASE TALK TO MANAGEMENT ABOUT FINDING WAY TO BETTER EVACUATE MOIOST AIR FROM RESTROOMS.

Site Report Generated: 6/23/2017 9:10:21 AM

Person In Charge

Inspection By: Mason Lyman

Page 4

Establishment: 2910200A
Inspection Type: BIANUL

Start Date/Time: 8/19/2014 at 11:50:47

Historical 8/19/2014

HOTEL/MOTEL INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
OREGON COAST HOSPITALITY
ECONOLODGE GARIBALDI
227 GARIBALDI AVE
GARIBALDI, OR 97118

Inspection Type: BIANUL
Inspection Result: COMPLD
Establishment #: 2910200A Area: 30
Units: 22
County: 29

ECONOLODGE GARIBALDI
4801 N INTERSTATE AVE
PORTLAND, OR 97217

Phone: (503) 322-2552 x
Inspector: Mason Lyman

Start Date/Time: 8/19/2014 at 11:50:47 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

CHECKED ROOMS 102 AND 103.

HOT WATER AT ALL SINKS
MATTRESS PADS ON BEDS PROVIDED
CLEAN SHEETS PRESENT
SMOKE DETECTORS WORK IN ALL ROOMS
BATHROOMS CLEAN, NO PESTS PRESENT.
MICROWAVES CLEAN
TEMPERATURES OF FRIDGE IN 103 WAS 49F, HAD THEM TURN IT DOWN TO MAINTAIN 45F OR LESS.
GARBAGE COLLECTION CLEAN.

LAUNDRY ROOM- SHELVING CLEANABLE, SMOOTH, SEPERATED FROM DIRTY LAUNDRY.
**CHEMICAL BOTTLES NEED A LABEL TO SPECIFY THEIR CONTENTS.
**REMOVE DUST DEBRIS/COBWEBS BUILD UP AROUND WATER HEATERS IN LAUNDRY ROOM FOR GENERAL MAINTENANCE.
STAIRWAYS CLEAR AND STRONG
FIRE EXTINGUISHERS LOCATED WITHIN 75 FEET OF ALL ROOMS.
LIGHT BULBS COVERED.

333-029-0045(5)(a)(b)

Violation for OAR 333-29-0045 (5)(a) or (b) The bathrooms, toilet rooms, laundry rooms, or similar rooms have insufficient mechanical ventilaton or screened window openings to comply with OAR 333-029-0045 (5)(a) or (b).

VENT IN BOTH BATHROOMS (ROOM 102 AND 103) DIDN'T PROVIDE SUCTION IN SYSTEM TO PROPERLY VENT ROOM

Provide natural or mechanical ventilation that meets the requirements of OAR 333-029-0045 (5)(a) 1 1/2 sq. ft. (0.14 sq. m) of openable window or skylight area, or; (b) Mechanical ventilation equaling 5 air changes per hour vented to the outside. Do not

PLEASE REPAIR VENTS

Establishment: 2910200A
Inspection Type: BIANUL

Page 6 of 9
Start Date/Time: 8/19/2014 at 11:50:47

Comments:

Site Report Generated: 6/23/2017 9:10:21 AM

Person In Charge

Inspection By: Mason Lyman

Page 6

Establishment: 2910200A
Inspection Type: ANNUAL

Page 7 of 9
Start Date/Time: 9/11/2013 at 12:56:05

Historical 9/11/2013

HOTEL/MOTEL INSPECTION REPORT

Page 7 of 9

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
OREGON COAST HOSPITALITY
ECONOLODGE GARIBALDI
227 GARIBALDI AVE
GARIBALDI, OR 97118

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910200A Area: 30
Units: 22
County: 29

ECONOLODGE GARIBALDI
4801 N INTERSTATE AVE
PORTLAND, OR 97217

Phone: (503) 322-2552 x
Inspector: Melissa Kauffman

Start Date/Time: 9/11/2013 at 12:56:05 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS AN ANNUAL INSPECTION

LAUNDRY ROOM IN GOOD REPAIR
GOOD STORAGE OF CHEMICLES
LIGHTS ARE PROTECTED
CLEAN AND SOILED LINENS ARE SEPARATE
ROOM IN GOOD REPAIR

WORKING SMOKE DETECTORS
FIRE EXTINGUISERS WITHIN 74FT
BED LINENS ARE CLEAN AND BEDS IN GOOD REPAIR
RESTROOMS VENTILATION GOOD IN 204
OVERALL FACILITY IS WELL MAINTAINED.

21 ROOMS ARE FOR RENT
2 ROOMS WERE INSPECTED

333-029-0045(4)(b)

Violation of OAR 333-029-0045 (4)(b) The dormitory has inadequate natural or mechanical ventilation.

THE FAN IN ROOM 104 WAS UNPLUGGED AND NOT WORKING

Repair or modify the ventilation system to meet the requirements of OAR 333-029-0045 (4)(b) - Mechanical ventilation must provide 2 air changes per hour, with 20% taken from outside Do not use the dormitory until adequate ventilation is provided.

PIC WILL REPAIR

Establishment: 2910200A
Inspection Type: ANNUAL

Page 8 of 9
Start Date/Time: 9/11/2013 at 12:56:05

Comments:

Site Report Generated: 6/23/2017 9:10:22 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 8

Establishment: 2910200A
Inspection Type: ANNUAL

Page 9 of 9
Start Date/Time: 9/20/2012 at 10:53:30

Historical 9/20/2012

HOTEL/MOTEL INSPECTION REPORT

Page 9 of 9

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
OREGON COAST HOSPITALITY
ECONOLODGE GARIBALDI
227 GARIBALDI AVE
GARIBALDI, OR 97118

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910200A Area: 30
Units: 22
County: 29

ECONOLODGE GARIBALDI
4801 N INTERSTATE AVE
PORTLAND, OR 97217

Phone: (503) 322-2552 x
Inspector: Melissa Kauffman

Start Date/Time: 9/20/2012 at 10:53:30 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION
ROOMS 103 AND 211 WERE INSPECTED
MATRESS PADS ON BEDS
GOOD VENTILATION IN THE BATHROOMS
MICROWAVE AND MINI FRIDGE ARE CLEAN
SMOKE DETECTORS ARE WORKING
FIRE EXTINGUISHERS ARE LOCATED WITHIN 75FT.

LAUNDRY ROOMS ARE IN GOOD REPAIR
GOOD SEPARATION OF CLEAN AND SOILED LINENS
CHEMICLES ARE PROPERLY STORED
LIGHTS ARE PROTECTED

THERE ARE NO VIOLATIONS AT THIS TIME THANK YOU!

Comments:

Site Report Generated: 6/23/2017 9:10:22 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 9