

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
SALT AIR CONDOMINIUM ASSOCIATION
GETAWAY OCEANFRONT LODGING
621 S PACIFIC
ROCKAWAY, OR 97136

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910058 Area: 30
Units: 13
County: 29

GETAWAY OCEANFRONT LODGING
3828 SE DIVISION
PORTLAND, OR 97202

Phone: (503) 355-2501 x
Inspector: Jaime Craig

Start Date/Time: 10/26/2016 at 2:02:00 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

12 RENTABLE ROOMS: CHECKED ROOMS #1 AND #3
HOTEL FLOODED LAST WINTER AND MOST UNITS ON LOWER LEVEL WERE REMODELED
PETS ALLOWED IN SOME ROOMS, NOT ALL- SPECIAL CLEANING AFTER PET USE.
FIRE EXTINGUISHERS SERVICED NOV 2015
MATTRESS PADS PROVIDE ON ALL BEDS
LINENS CLEAN
MICROWAVES CLEAN
FRIDGES CLEAN/COLD
DISHES IN GOOD REPAIR
NO EVIDENCE OF MOLD OR MILDEW
NO EVIDENCE OF PESTS OR RODENTS
HANDRAILS STURDY AND IN GOOD REPAIR
GARBAGE SERVICE WEEKLY
LAUNDRY ROOM:
CHEMICALS LABELED AND STORED AWAY FROM CLEAN LINENS
GOOD SEPARATION OF CLEAN AND DIRTY LINENS
LIGHT BULBS PLASTIC
**UNIT #3 HAS NO SMOKE DETECTOR-PLEASE PROVIDE A SMOKE DETECTOR IN ROOM
**PLEASE DO NOT KEEP CHEMICALS ON SAME SHELVES AS PAPER PRODUCTS IN CASE OF SPILL IN HOUSE KEEPING CLOSET.
**SEAL ALL RAW WOOD OF SHELVES IN HOUSEKEEPING CLOSET SO THEY ARE EASILY CLEANABLE.

**PLEASE REPLACE DUST RUFFLE IN UNIT #1 WITH NON STAINED ONES

**GAVE OUT 12 SIGNS FOR CUPBOARDS ABOUT EXTRA SANITATION FOR SIGNS IF NEEDED.

333-029-0040

Violation of OAR 333-029-0040 The facility's equipment, fixtures, furnishings or premises are not being kept clean and in good repair so as to protect health, safety, and well being of persons using those facilities.

CEILING IN LAUNDRY ROOM IN DISREPAIR-MISSING CHUNKS AND RAW BEAMS EXPOSED

Maintain, clean, or repair the facility and its components in compliance with OAR 333-029-0040.

PLEASE REPAIR

Establishment: 2910058
Inspection Type: ANNUAL

Page 2 of 7
Start Date/Time: 10/26/2016 at 2:02:00

Comments:

Site Report Generated: 6/23/2017 2:27:55 PM

Person In Charge

Inspection By: Jaime Craig

Page 2

Establishment: 2910058
Inspection Type: ANNUAL

Page 3 of 7
Start Date/Time: 10/28/2015 at 3:31:28

Historical 10/28/2015

HOTEL/MOTEL INSPECTION REPORT

Page 3 of 7

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
SALT AIR CONDOMINIUM ASSOCIATION
GETAWAY OCEANFRONT LODGING
621 S PACIFIC
ROCKAWAY, OR 97136

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910058 Area: 30
Units: 13
County: 29

GETAWAY OCEANFRONT LODGING
3828 SE DIVISION
PORTLAND, OR 97202

Phone: (503) 355-2501 x
Inspector: Mason Lyman

Start Date/Time: 10/28/2015 at 3:31:28 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

12 ROOMS TOTAL-

INSPECTED ROOM #8-
DISHES CLEAN AND NOT BROKEN
HOT WATER PLUMBED
FIRE ALARMS WORKING
FIRE EXT WITHIN 75 FEET OF ROOMS
SHEETS FREE OF DEBRIS
MATTRESS PADS PROVIDED
NO MOLD/MILDEW PRESENT
NO EVIDENCE OF RODENTS/ PESTS
GARBAGE COLLECTION AREA SAFE/ OFF THE GROUND
GOOD SEPARATION AT LAUNDRY AREA

333-029-0100(2)

Violation of OAR 333-029-0100 (2) Toxic substances are not clearly and accurately labeled or identified.

SPRAY BOTTLES IN LAUNDRY NOT ACCURATELY LABELED. REPEAT VIOLATION.

Clearly identify each toxic chemical container and label all toxic chemicals as toxic.

PLEASE CORRECT.

**PROVIDE SHIELDING FOR NEW LIGHT BULBS IN LAUNDRY AREA.

**PROVIDE SCREEN ON LAUNDRY WINDOW (ON THE INSIDE).

Site Report Generated: 6/23/2017 2:27:55 PM

Person In Charge

Inspection By: Mason Lyman

Page 3

Establishment: 2910058
Inspection Type: ANNUAL

Page 4 of 7
Start Date/Time: 10/13/2014 at 2:15:33

Historical 10/13/2014

HOTEL/MOTEL INSPECTION REPORT

Page 4 of 7

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
SALT AIR CONDOMINIUM ASSOCIATION
GETAWAY OCEANFRONT LODGING
621 S PACIFIC
ROCKAWAY, OR 97136

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910058 Area: 30
Units: 13
County: 29

GETAWAY OCEANFRONT LODGING
3828 SE DIVISION
PORTLAND, OR 97202

Phone: (503) 355-2501 x
Inspector: Mason Lyman

Start Date/Time: 10/13/2014 at 2:15:33 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

14 ROOMS TOTAL-
CHECKED ROOM 1 AND 2

ADEQUATE HOT WTER
MATTRESS PADS ON BEDS
CLEAN SHEETS PROVIDED
SMOKE DETECTORS WORKING
NO MOLD/MILDEW PRESENT IN BATHROOMS
NO VISIBLE PRESENCE OF PESTS/RODENTS
GARBAGE COVERED/OFF GROUND/DUMPED REGULARLY.
SCREENS ON WINDOWS
DISHES IN GOOD REPAIR.

LAUNDRY ROOM-
SHELVES SEALED
CHEMICALS STORED SAFELY
GOOD SEPARATION BETWEEN DIRTY AND CLEAN LINENS
STAIRWAYS SOLID
FIRE EXTINGUISHERS WITHIN 75 FEET OF ALL ROOMS

**PROVIDE SHIELD FOR LIGHT BULBS IN LAUNDRY AREA.

333-029-0100(2)

Violation of OAR 333-029-0100 (2) Toxic substances are not clearly and accurately labeled or identified.

1 TOXIC BOTTLE FOUND WITHOUT LABEL

Clearly identify each toxic chemical container and label all toxic chemicals as toxic.

CORRECTED- LABEL PLACED ON ALL SPRAY BOTTLES.

Establishment: 2910058
Inspection Type: ANNUAL

Page 5 of 7
Start Date/Time: 10/13/2014 at 2:15:33

Comments:

Site Report Generated: 6/23/2017 2:27:55 PM

Person In Charge

Inspection By: Mason Lyman

Page 5

Establishment: 2910058
Inspection Type: ANNUAL

Page 6 of 7
Start Date/Time: 3/19/2013 at 10:40:37

Historical 3/19/2013

HOTEL/MOTEL INSPECTION REPORT

Page 6 of 7

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
SALT AIR CONDOMINIUM ASSOCIATION
GETAWAY OCEANFRONT LODGING
621 S PACIFIC
ROCKAWAY, OR 97136

Inspection Type: ANNUAL
Inspection Result: COMPLD
Establishment #: 2910058 Area: 30

Units: 13
County: 29

GETAWAY OCEANFRONT LODGING
3828 SE DIVISION
PORTLAND, OR 97202

Phone: (503) 355-2501 x
Inspector: Melissa Kauffman

Start Date/Time: 3/19/2013 at 10:40:37 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION.

TWO ROOMS WERE INSPECTED
MATRESS PADS ON BEDS
GOOD VENTILATION IN BATHROOMS
SHOWERS AND FLOORING IS IN GOOD REPAIR
FIRE EXTINGUISHERS ARE PRESENT OUTSIDE OF ROOMS
SMOKE DETECTORS ARE WORKING
GOOD SIGNS FOR PATRON DISHWASHING
ROOMS ARE IN VERY GOOD CONDITION
LAUNDRY ROOMS IS IN GOOD REPAIR
LIGHTS ARE SHATTER PROOF
GOOD SEPARATION OF CLEAN AND SOILED LINENS
CHEMICLES ARE PROPERLY ORGANIZED

THERE ARE NO VIOLATIONS AT THIS TIME THANK YOU!

Establishment: 2910058
Inspection Type: ANNUAL

Page 7 of 7
Start Date/Time: 3/19/2013 at 10:40:37

Comments:

Site Report Generated: 6/23/2017 2:27:55 PM

Person In Charge

Inspection By: Melissa Kauffman

Page 7