

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
MIKE MCLEOD
NESKOWIN CREEK RV RESORT
50500 S HWY 101
NESKOWIN, OR 97149

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920002B Area: 31
Units: 115
County: 29

NESKOWIN CREEK RV RESORT
50500 S HWY 101
NESKOWIN, OR 97149

Phone: (503) 392-3355 x
Inspector: Jaime Craig

Start Date/Time: 2/8/2017 at 10:28:20 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

PERSON IN CHARGE EASILY FOUND (JIM)
SEWER SLOPING-GOOD
BATHROOMS CLEAN AND WELL STOCKED OVERALL MAINTANCE OF PARK IS GOOD
PICNIC TABLES AND FIRE PITS IN GOOD REPAIR EACH SITE IDENTIFIED WITH A NUMBER
GARBAGE SERVICE REGULARLY
SPACING OF SITE IS AT LEAST 10 FT.
LAUNDRY ROOM LOOKS GOOD
5 PARK MODELS (INSPECTED SALMON RUN
**DISCARDED 3 CUTTING BOARDS, 1 POT, AND ONE PAN FROM THE UNIT. LIGHTS IN BATHROOM NEED TO BE SHILEDDED OR COVERED, OR PLASTIC BULBS NEED TO BE INSTALLED.

333-031-0004(4)

Violation of OAR 333-031-0004 (4) The plumbing system is not in compliance with the applicable provisions of the Oregon Plumbing Specialty Code.

BACK FLOW PREVENTORS REQUIRED ON ALL SITES.

Bring the plumbing into compliance with the Oregon Plumbing Specialty Code. Specifically:

MISSING ON #10,13,14,15,39,41, 51,52,56,57, 82 (ONLY CHECKED 100 SITES, NOT SITES AS YOU FIRST DRIVE IN OR NEAR POOL HOUSE.

333-031-0008(1)

Violation of OAR 333-031-0008 (1) Insect and rodent control measures are not effective in protecting the public health, preventing a nuisance to the public or accumulations of debris are noted.

EXCESS BUNNIES IN PARK

Apply insect and rodent control measures, including maintenance of developed areas, buildings and structures, to be free of accumulating debris, to prevent nuisance to the public and to safeguard the public health.

OPERATOR ATTEMPTS TO LIMIT POPULATION GROWTH

Establishment: 2920002B

Page 2 of 11

Inspection Type: SEMI

Start Date/Time: 2/8/2017 at 10:28:20

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Jaime Craig

Page 2

Historical 9/19/2016

RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Jaime Craig

Start Date/Time: 9/19/2016 at 2:35:08 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

PERSON IN CHARGE EASY TO FIND
SEWER SLOPING-GOOD
BATHROOMS CLEAN AND WELL STOCKED
OVERALL MAINTAINED -GOOD
PICNIC TABLES AND FIRE PITS IN GOOD REPAIR
GOOD FLOW OF TRAFFIC IN PARK
EACH SITE IDENTIFIED
GARBAGE SERVICE REGULARLY

333-031-0004(4)

Violation of OAR 333-031-0004 (4) The plumbing system is not in compliance with the applicable provisions of the Oregon Plumbing Specialty Code.

Bring the plumbing into compliance with the Oregon Plumbing Specialty Code. Specifically:

ANTI-SIPHON DEVICES REQUIRED AT ALL WATER SOURCE SITES

333-031-0008(1)

Violation of OAR 333-031-0008 (1) Insect and rodent control measures are not effective in protecting the public health, preventing a nuisance to the public or accumulations of debris are noted.

EXCESSIVE RABBITS ON SITE

Apply insect and rodent control measures, including maintenance of developed areas, buildings and structures, to be free of accumulating debris, to prevent nuisance to the public and to safeguard the public health.

OPERATOR ATTEMPTS TO LIMIT POPULATION GROWTH

Establishment: 2920002B

Page 4 of 11

Inspection Type: SEMI

Start Date/Time: 9/19/2016 at 2:35:08

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Jaime Craig

Page 4

Historical 3/15/2016

RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Mason Lyman

Start Date/Time: 3/15/2016 at 11:09:48 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

SEMIANNUAL INSPECTION OF RV PARK-

- BACKFLOW PREVENTERS ON MOST FAUCETS
- ALL SITES EASILY IDENTIFIABLE
- GOOD SPACING BETWEEN SITES
- GARBAGE COLLECTION AREA SAFE
- RESTROOMS CLEAN/WELL MAINTAINED
- GOOD FLOW OF TRAFFIC AROUND SITE
- OUTSIDE OF BUILDINGS IN GOOD CONDITION

**NEW SIGN RECENTLY TO SHOW DANGERS OF BUNNIES IN PARK- GREAT JOB.

333-031-0006(3)

Violation of OAR 333-031-0006 (3) Liquid waste has been discharged, or ponded on the ground surfqce.

SEVERAL SITES (#64, AND OTHERS) HAD SEWER LINES GOING UPHILL.

Dispose of all sewage and waste water into a public sewerage system or in a manner approved by the DEQ OAR 340-071-0100 to 333-071-0650. Specifically:

PLEASE NOTIFY CUSTOMERS ABOUT SEWER LINES TO DRAIN FREELY AND PREVENT POOLING ON THE GROUND.

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Historical 8/14/2015

RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Mason Lyman

Start Date/Time: 8/14/2015 at 11:01:33 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

INSPECTION OF RV PARK-

- BACKFLOW PREVENTERS ON MOST FAUCETS
- SEWER LINES MOSTLY SLOPED CORRECTLY
- GOOD FLOW OF TRAFFIC AROUND PARK
- GOOD SPACING BETWEEN SITES
- SITES EASILY IDENTIFIED
- PIC EASILY FOUND ON SITE
- RESTROOMS IN GREAT CONDITION
- OUTSIDE OF BUILDINGS CLEAN/WELL MAINTAINED

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Mason Lyman

Establishment: 2920002B

Inspection Type: SEMI

Start Date/Time: 1/20/2015 at 2:33:13

Historical 1/20/2015 RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Mason Lyman

Start Date/Time: 1/20/2015 at 2:33:13 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

SEMIANNUAL INPECTION OF PARK-

BACKFLOW DEVICES ON MOST FAUCETS, KEEP UP ON REPLACING THEM.

PIC EASILY FOUND, GOOD SECURITY

GARBAGE COLLECTION DONE WELL, KEPT OFF GROUND AND PROTECTED

OUTSIDE OF BUILDINGS IN GOOD REPAIR

EACH PARK SITE IS EASILY IDENTIFIED AND READABLE

GOOD FLOW OF TRAFFIC IN PARK AND NO BLOCKAGES OF RAODWAYS

RESTROOMS ARE CLEAN, MADE OF CLEANABLE SURFACES, PROVIDE GOOD VENTILATION AND HAVE HOT WATER PROVIDED.

**SITE NUMBER 5 HAS AN IMPROPERLY SLOPED SEWER LINE. PLEASE CORRECT AND WALK THROUGH PARK FROM TIME TO TIME TO CORRECT AS NEEDED.

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Mason Lyman

Historical 7/31/2014

RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Mason Lyman

Start Date/Time: 7/31/2014 at 12:14:46 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

SEMIANNUAL INSPECTION.

BACKFLOW PREVENTER INSTALLED THROUGH THE PARK.

SEWER LINES SLOPED CORRECTLY AND DRAINING PROPERLY.

SPOTS EVENLY SPACED AND VEHICLES ARE AT LEAST 10 FEET APART FROM EACH OTHER.

SPACES ARE BRIGHTLY MARKED AND EASILY IDENTIFIED.

RESTROOMS ARE CLEAN, AND INCLUDE PROPER VENTILATION.

PARK IS CLEAN THROUGHOUT AND MAINTAIN HYGIENIC ENVIRONMENT.

NO PESTS SEEN, AND OUTSIDE OF BUILDINGS ARE CLOSED TO PREVENT PEST AND ANIMAL CONTROL PROBLEM.

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Mason Lyman

Establishment: 2920002B

Page 9 of 11

Inspection Type: SEMI

Start Date/Time: 10/3/2013 at 10:55:05

Historical 10/3/2013

RECREATIONAL PARK INSPECTION REPORT

Page 9 of 11

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Melissa Kauffman

Start Date/Time: 10/3/2013 at 10:55:05 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE RV PARK

THE MAJORITY OF CAMP SITES HAVE PROPERLY SLOPED SEWAGE LINES 3,7,AND 24 NEED TO SLOPE THEIR LINES

ALL WATER SPIGOTS THAT WERE CHECKED HAVE BACKFLOW PREVENTORS SITE 46 HAS A STEADY WATER LEAK

CAMP SITES ARE EASILY IDENTIFIABLE

CAMP SITES ARE PROPERLY ASSIGNED TO ONE CAMPING VEHICLE PER SITE

CAMP GROUNDS ARE IN VERY GOOD REPAIR

GARBAGE AND RECYCLING ARE PROPERLY STORED

RESTROOMS ARE CLEAN AND SHOWERS ARE IN GOOD REPAIR.

NO VIOLATIONS AT THIS TIME, THANK YOU

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 9

Establishment: 2920002B

Page 10 of 11

Inspection Type: SEMI

Start Date/Time: 4/30/2013 at 1:23:51

Historical 4/30/2013

RECREATIONAL PARK INSPECTION REPORT

Page 10 of 11

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MIKE MCLEOD

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920002B Area: 31

Units: 115

County: 29

NESKOWIN CREEK RV RESORT

50500 S HWY 101

NESKOWIN, OR 97149

Phone: (503) 392-3355 x

Inspector: Melissa Kauffman

Start Date/Time: 4/30/2013 at 1:23:51 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION.

RV SITES ARE PROPERLY ORGANIZED

SEWAGE LINES ARE SLOPPED

GROUNDNS ARE IN GREAT CONDITION

RESTROOMS ARE IN GREAT REPAIR

GARBAGE IS PROPERLY STORED

NO PRESENCE OF PESTS

THERE ARE NO VIOLATIONS AT THIS TIME THANK YOU!

*BACK FLOW PREVENTORS ARE BEING REPLACED AFTER A FULL PARK

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 10

Historical 9/4/2012 RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MIKE MCLEOD
NESKOWIN CREEK RV RESORT
50500 S HWY 101
NESKOWIN, OR 97149

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920002B Area: 31
Units: 115
County: 29

NESKOWIN CREEK RV RESORT
50500 S HWY 101
NESKOWIN, OR 97149

Phone: (503) 392-3355 x
Inspector: Melissa Kauffman

Start Date/Time: 9/4/2012 at 11:53:38 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE RV PARK

ALL SITES ARE CLEARLY MARKED
ALL SEWAGE LINES ARE SLOPED
CAMP GROUNDS ARE VERY CLEAN AND IN GOOD CONDITION
THE RESTROOMS AND SHOWER ARE IN GREAT CONDITION

333-031-0004(4)

Violation of OAR 333-031-0004 (4) The plumbing system is not in compliance with the applicable provisions of the Oregon Plumbing Specialty Code.

SEVERAL SITES ARE MISSING BACKFLOW DEVICES SPECIFICALLY 89,32,57,80

Bring the plumbing into compliance with the Oregon Plumbing Specialty Code. Specifically:

PLEASE REPLACE

Comments:

Site Report Generated: 6/23/2017 9:56:28 AM

Person In Charge

Inspection By: Melissa Kauffman