

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:

NORTH COUNTY RECREATION DISTRICT
NORTH COUNTY RECREATION DISTRICT
36155 9TH STREET
NEHALEM, OR 97131

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940001 Area: 60

Units: 0
County: 29

NORTH COUNTY RECREATION DISTRICT
PO BOX 207
NEHALEM, OR 97131

Phone: (503) 368-7008 x
Inspector: Jaime Craig

Start Date/Time: 1/18/2017 at 12:27:17 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

POOL CHEMISTRY ALL OKAY
LOG BOOK IN ORDER, CHEMS TAKEN EVERY 4 HRS
SHOCK CHLORINATED AS NEEDED
POOL CHEMICALS STORED SEPRATE
PUMP ROOM , CLEAN AND WELL ORGANIZED
SEVERAL EXTRA CARTRIDGE FILTERS AVAILABLE
CLEANED AT 18 PSI
ALL SAFETY EQUIPMENT AVAILABLE
SIGNS POSTED AS NEEDED
RESTROOMS VERY CLEAN
POOL AREA ORGANIZED AND CLEAN
HANDRAILS, ALL INTACT
NO MAIN DRAIN, POOL HAS SKIMMERS
FIRST AID KIT- A FEW SUPPLIES NEEDED
BLEACH BOTTLE TO BE REMOVED FROM SWIMMER ACCESS
PHONE AVAILABLE ON DECK

Free Chlorine (0.8-5.0 ppm):	1.0	Bromine (3.0-8.0 ppm):	Temperature(F):	86	
Combined Chlorine (0-.5 ppm):	0.5	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y	
Total Alkalinity (80-200 ppm):	111	Hardness (175-400 ppm):	300	pH (7.2-7.6):	7.3
Inlet Pressure:		Outlet Pressure:	Flow Rate:	80	
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):	800				

Establishment: 2940001

Page 2 of 12

Inspection Type: SEMI

Start Date/Time: 1/18/2017 at 12:27:17

Comments:

Site Report Generated: 6/23/2017 9:53:55 AM

Person In Charge

Inspection By: Jaime Craig

Page 2

Historical 9/23/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

NORTH COUNTY RECREATION DISTRICT
NORTH COUNTY RECREATION DISTRICT
36155 9TH STREET
NEHALEM, OR 97131

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940001 Area: 60

Units: 0
County: 29

NORTH COUNTY RECREATION DISTRICT
PO BOX 207
NEHALEM, OR 97131

Phone: (503) 368-7008 x
Inspector: Mason Lyman

Start Date/Time: 9/23/2015 at 2:02:59 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

INSPECTION OF FACILITY-

- SKIMMERS OK
- GATES/DOORS OK
- AIR VENTILATION OK
- STAIRS/LADDERS OK
- SAFETY EQUIPMENT OK
- BACK BOARDS/ FIRST AID KIT/ BLOOD BORNE PATHOGEN KIT ALL OK
- PHONE INSTALLED
- LOCKER ROOMS CLEAN/ WELL MAINTAINED
- NOT USING MAIN DRAIN
- REDID DECK PAINT OVER THE SUMMER

Free Chlorine (0.8-5.0 ppm):	2.6	Bromine (3.0-8.0 ppm):		Temperature(F):	88
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	70	Hardness (175-400 ppm):	140	pH (7.2-7.6):	7.2
Inlet Pressure:		Outlet Pressure:		Flow Rate:	316

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

333-060-0200(3)(4)

VIOLATION OF OAR 333-060-0200 (3) & (4) The pool water quality parameters are not tested at the required frequencies or are not recorded.

FACILITY NOT TESTING FOR COMBINED CHLROINE ON REGULAR BASIS (SEVERAL TIMES A WEEK).

Complete and record the required pool water tests at the minimum frequencies as described in OAR 333-060-0200 (3)(a) to (3)(j), or as required by the Division or local public health authority.

PLEASE RECORD AND MEASURE COMBINED CHLORINE WHENEVER MEASURING/RECORDING FREE CHLORINE.

Establishment: 2940001

Page 4 of 12

Inspection Type: SEMI

Start Date/Time: 9/23/2015 at 2:02:59

**RECOMMEND PUTTING ON RECORD SHEET ON WHEN/HOW MUCH OF WHICH CHEMICALS DID YOU MANUALLY ADD TO POOL.

Site Report Generated: 6/23/2017 9:53:55 AM

Person In Charge

Inspection By: Mason Lyman

Page 4

Historical 3/3/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

NORTH COUNTY RECREATION DISTRICT
NORTH COUNTY RECREATION DISTRICT
36155 9TH STREET
NEHALEM, OR 97131

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940001 Area: 60
Units: 0
County: 29

NORTH COUNTY RECREATION DISTRICT
PO BOX 207
NEHALEM, OR 97131

Phone: (503) 368-7008 x
Inspector: Mason Lyman

Start Date/Time: 3/3/2015 at 1:57:01 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SIGNS/ SAFETY EQUIPMENT OK

FIRST AID KIT AND BLOOD BORNE PATHOGEN KIT STOCKED (KEEP BLEACH STOCKED AS WELL)

LADDERS/ STAIRS OK

LOCKER ROOMS FOUND WITHOUT HAZARDS

TURNOVER IS UNDER THE REQUIRED 6 HOURS

REPLACING COVERS AND SCREWS ALONG DECK SURFACE AS WELL AS REPAINT DECK SURFACE SCHEDULED IN JUNE.

GOOD DATING OF CHEMICAL BOTTLES IN POOL ROOM.

DRAINS IN WORKING ORDER

Free Chlorine (0.8-5.0 ppm):	3.0	Bromine (3.0-8.0 ppm):		Temperature(F):	88
Combined Chlorine (0-.5 ppm):	.2	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	80	Hardness (175-400 ppm):	150	pH (7.2-7.6):	7.2
Inlet Pressure:		Outlet Pressure:		Flow Rate:	310
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

333-060-0200(1.11)

VIOLATION OF OAR 333-060-0200 (1) The calcium hardness is less than 175 ppm.

WATER HARDNESS AT 150 PPM.

The recommended minimum level of calcium hardness is 175 ppm, per OAR 333-60-200 and Table 3. Most pools need about 250 - 300 ppm of calcium hardness. Low calcium hardness can create corrosive conditions in the pool

Add calcium chloride to increase t

**READING SHOULD BE BETWEEN 175-400 PPM, IDEALLY BETWEEN 250-300 PPM.
PLEASE CORRECT (NON-CLOSURE ITEM).**

333-060-0200(3)(4)

VIOLATION OF OAR 333-060-0200 (3) & (4) The pool water quality parameters are not tested at the required frequencies or are not recorded.

FREE CHLORINE AND COMBINED CHLORINE ARE NOT BEING TESTED OFTEN ENOUGH

Complete and record the required pool water tests at the minimum frequencies as described in OAR 333-060-0200 (3)(a) to (3)(j), or as required by the Division or local public health authority.

PLEASE TEST FOR FC AND CC EVERY 4 HOURS DURING POOL OPERATION. PLEASE GIVE PROPER TOOLS TO TESTING PERSONNEL TO COMPLETE ASSIGNMENT.

Comments:

Site Report Generated: 6/23/2017 9:53:55 AM

Person In Charge

Inspection By: Mason Lyman

Page 6

Establishment: 2940001

Page 7 of 12

Inspection Type: SEMI

Start Date/Time: 8/25/2014 at 2:07:37

Historical 8/25/2014

POOL PROGRAM INSPECTION REPORT

Page 7 of 12

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

NORTH COUNTY RECREATION DISTRICT
NORTH COUNTY RECREATION DISTRICT
36155 9TH STREET
NEHALEM, OR 97131

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940001 Area: 60

Units: 0
County: 29

NORTH COUNTY RECREATION DISTRICT
PO BOX 207
NEHALEM, OR 97131

Phone: (503) 368-7008 x
Inspector: Mason Lyman

Start Date/Time: 8/25/2014 at 2:07:37 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

RESTROOMS ARE CLEAN
SHOWERROOM AVAILABLE
CAL HYPO AS SANITIZER
LADDERS OK
POOL DECK OK
ENCLOSURES OK
VENTS WORKING OK

**EMERGENCY PHONES PRESENT, PLEASE PROVIDE ADDRESS OF FACILITY AT BOTH LOCATIONS FOR EMERGENCY PERSONNEL.

USUALLY 3 LIFEGUARDS ON STATION.

AED DEVICE ON SITE

NO DIVING SIGNS PRESENT AND VISIBLE

GOOD CLARITY

Free Chlorine (0.8-5.0 ppm):	2.1	Bromine (3.0-8.0 ppm):		Temperature(F):	87
Combined Chlorine (0-.5 ppm):	.3	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	80	Hardness (175-400 ppm):	130	pH (7.2-7.6):	7.3
Inlet Pressure:		Outlet Pressure:		Flow Rate:	0

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

Establishment: 2940001

Page 8 of 12

Inspection Type: SEMI

Start Date/Time: 8/25/2014 at 2:07:37

Comments:

Site Report Generated: 6/23/2017 9:53:55 AM

Person In Charge

Inspection By: Mason Lyman

Page 8

Historical 11/6/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

NORTH COUNTY RECREATION DISTRICT
NORTH COUNTY RECREATION DISTRICT
36155 9TH STREET
NEHALEM, OR 97131

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940001 Area: 60

Units: 0
County: 29

NORTH COUNTY RECREATION DISTRICT
PO BOX 207
NEHALEM, OR 97131

Phone: (503) 368-7008 x
Inspector: Melissa Kauffman

Start Date/Time: 11/6/2013 at 9:53:32 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE POOL

- CLARITY IS GOOD
- GOOD SIGNS FOR PATRON SAFETY
- LOCKER ROOMS ARE IN GOOD REPAIR
- SHOWERS ARE AVAILABLE
- GOOD PHONE FOR EMERGENCY 2 ON DECK
- CERTIFIED LIFEGUARDS ON DUTY
- LADDERS ARE SECURE
- POOL ROOM IS PROPERLY ORGANIZED
- CHEMICLES ARE PROPERLY STORED
- CAL-HYPO FOR SANITATION
- GOOD RECORD KEEPING
- GOOD DEMONSTRATION OF KNOWLEDGE

Free Chlorine (0.8-5.0 ppm):	2.2	Bromine (3.0-8.0 ppm):		Temperature(F):	89
Combined Chlorine (0-.5 ppm):	.0	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	70	Hardness (175-400 ppm):	150	pH (7.2-7.6):	7.3
Inlet Pressure:		Outlet Pressure:		Flow Rate:	330
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

Establishment: 2940001

Page 10 of 12

Inspection Type: SEMI

Start Date/Time: 11/6/2013 at 9:53:32

Comments:

Site Report Generated: 6/23/2017 9:53:55 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 10

Historical 5/14/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

NORTH COUNTY RECREATION DISTRICT
NORTH COUNTY RECREATION DISTRICT
36155 9TH STREET
NEHALEM, OR 97131

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940001 Area: 60

Units: 0
County: 29

NORTH COUNTY RECREATION DISTRICT
PO BOX 207
NEHALEM, OR 97131

Phone: (503) 368-7008 x
Inspector: Melissa Kauffman

Start Date/Time: 5/14/2013 at 11:23:21 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION.

MSDS SHEETS ARE AVAILABLE
ALL NECESSARY POOL SAFETY EQUIPMENT PROVIDED
CERTIFIED LIFE GUARD ON DUTY
CPO ON STAFF
GOOD RECORD KEEPING
GOOD DATEMARKING OF CHEMICALS
CALCIUM HYPOCHLORITE IS USED FOR CHLORINE
AUTOMATED SYSTEM IS CALIBRATED TO TAYLOR TEST KIT.

TUESDAY IS POOL DAY FOR LOCAL SCHOOL AND POOL IS EXPERIENCING A HIGH BATHER LOAD.

Free Chlorine (0.8-5.0 ppm):	1.4	Bromine (3.0-8.0 ppm):		Temperature(F):	85
Combined Chlorine (0-.5 ppm):	.5	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	70	Hardness (175-400 ppm):	150	pH (7.2-7.6):	7.4
Inlet Pressure:		Outlet Pressure:		Flow Rate:	4.3

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

Establishment: 2940001

Page 12 of 12

Inspection Type: SEMI

Start Date/Time: 5/14/2013 at 11:23:21

TURNOVER IS 344 = EVERY 4.3HRS FOR A 90,000GAL POOL .
GREAT DEMONSTRATION OF KNOWLEDGE
WOMENS LOCKER ROOM APPEARS TO BEIN GOOD CONDITIOIN
POOL BASIN IS NEWLY PAINTED LAST SEPTEMBER
THERE ARE NO VIOLATIONS AT THIS TIME THANK YOU!

Site Report Generated: 6/23/2017 9:53:55 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 12