

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Jaime Craig

Start Date/Time: 11/9/2016 at 2:35:28 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

ATTEMPTED TO INSPECT-CLOSED OCT FOR THE SEASON

Free Chlorine (0.8-5.0 ppm):	Bromine (3.0-8.0 ppm):	Temperature(F):
Combined Chlorine (0-.5 ppm):	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):
Total Alkalinity (80-200 ppm):	Hardness (175-400 ppm):	pH (7.2-7.6):
Inlet Pressure:	Outlet Pressure:	Flow Rate:
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):		

Comments:

Site Report Generated: 6/20/2017 8:09:16 AM

Person In Charge

Inspection By: Jaime Craig

Historical 3/28/2016

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 3/28/2016 at 2:48:44 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SEMIANNUAL INSPECTION OF POOL-

- SKIMMERS OK
- GATES/OUTER DOORS OK
- LADDERS/STAIRS OK
- CLARITY IS GOOD
- AIR TEMPERATURE IS GOOD- CONSIDER REMOVING HUMIDITY FROM ROOM TO PREVENT BUILDUP AND CORROSION OF MATERIALS.
- EMERGENCY PHONE AVAILABLE IN GAME ROOM NEARBY- WORKING.
- SAFETY EQUIPMENT OK
- SIGNS UP
- MARKINGS OK

Free Chlorine (0.8-5.0 ppm):	3.0	Bromine (3.0-8.0 ppm):	Temperature(F):	84	
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y	
Total Alkalinity (80-200 ppm):	130	Hardness (175-400 ppm):	120	pH (7.2-7.6):	7.4
Inlet Pressure:		Outlet Pressure:		Flow Rate:	0

333-060-0200(1.11)

VIOLATION OF OAR 333-060-0200 (1) The calcium hardness is less than 175 ppm.

HARDNESS AT 120 PPM.

The recommended minimum level of calcium hardness is 175 ppm, per OAR 333-60-200 and Table 3. Most pools need about 250 - 300 ppm of calcium hardness. Low calcium hardness can create corrosive conditions in the pool

Add calcium chloride to increase t

PLEASE INCREASE TO 200-300 PPM.

Establishment: 2940018A

Page 3 of 11

Inspection Type: SEMI

Start Date/Time: 3/28/2016 at 2:48:44

KEEP TRACK OF AMOUNTS OF CHEMICALS IN WEIGHT WHEN PUTTING IN POOL/SPA, RECORD IN RECORDS.

Site Report Generated: 6/20/2017 8:09:17 AM

Person In Charge

Inspection By: Mason Lyman

Page 3

Historical 9/22/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 9/22/2015 at 3:59:12 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

- GOOD TURNOVER
- GOOD RECORD KEEPING
- GATES"DOORS OK
- DECK SURFACE / ENCLOSURE OK
- SKIMMERS OK
- POOL RULES OK
- SAFETY EQUIPMENT OK

Free Chlorine (0.8-5.0 ppm):	0.8	Bromine (3.0-8.0 ppm):		Temperature(F):	86
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	120	Hardness (175-400 ppm):	400	pH (7.2-7.6):	7.6
Inlet Pressure:		Outlet Pressure:		Flow Rate:	260
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

**INCLUDE COMBINED CHLORINE TESTING IN POOL CHEMISTRY.

Site Report Generated: 6/20/2017 8:09:17 AM

Historical 3/26/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 3/26/2015 at 3:31:24 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

INSPECTION OF POOL-
SIGNS/ SAFETY EQUIPMENT OK
SKIMMERS OK
GATES/ DOORS OK
LADDERS/ STAIRS OK
ENCLOSURE SAFE
NO GLASS AND VISIBLE SAFETY ISSUES
DECK SURFACE CLEAN AND WITHOUT LARGE OBSTRUCTIONS.
GOOD RECORD KEEPING.

Free Chlorine (0.8-5.0 ppm):	0.8	Bromine (3.0-8.0 ppm):	Temperature(F):	85
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	60	Hardness (175-400 ppm):	400	pH (7.2-7.6):
Inlet Pressure:		Outlet Pressure:		7.6
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):				225

333-060-0200(1.09)

VIOLATION OF OAR 333-060-0200 (1) The total alkalinity is less than 80 ppm or greater than 200 ppm. Specifically:

ALKALINTIY READING AT 60 PPM.

Maintain the total alkalinity within the range set out in the pool Water Quality Parameters, OAR 333-060-0200 and Table 3, ideal being approximately 80 - 125 ppm total alkalinity. Most modern pool finishes are durable within this range as long as the cal

PLEASE INCREASE TO GET ABOVE 80 PPM.

Establishment: 2940018A

Page 6 of 11

Inspection Type: SEMI

Start Date/Time: 3/26/2015 at 3:31:24

Comments:

Site Report Generated: 6/20/2017 8:09:17 AM

Person In Charge

Inspection By: Mason Lyman

Page 6

Historical 8/20/2014

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 8/20/2014 at 12:44:43 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

GATES/DOORS OK
SAFETY EQUIPMENT OK
SIGNS OK
RECORDS OK
CLEAR WATER

****FREE CHLORINE SHOULD BE CHECKED DAILY**

Free Chlorine (0.8-5.0 ppm):	2.2	Bromine (3.0-8.0 ppm):		Temperature(F):	85
Combined Chlorine (0-.5 ppm):	.2	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	90	Hardness (175-400 ppm):	500	pH (7.2-7.6):	7.4
Inlet Pressure:		Outlet Pressure:		Flow Rate:	0
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

333-060-0045(2)

VIOLATION OF OAR 333-060-0045 (2) The pool structural components or the structural components of an appurtenance are in poor repair.

POOL LADDER WITH BROKEN STEP

Repair and maintain the pool structure or the appurtenances. Specifically:

PLEASE REPAIR

Comments:

Site Report Generated: 6/20/2017 8:09:17 AM

Historical 10/16/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Melissa Kauffman

Start Date/Time: 10/16/2013 at 12:00:33 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE POOL IS CLOSED FOR THE SEASON

Free Chlorine (0.8-5.0 ppm):	Bromine (3.0-8.0 ppm):	Temperature(F):
Combined Chlorine (0-.5 ppm):	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):
Total Alkalinity (80-200 ppm):	Hardness (175-400 ppm):	pH (7.2-7.6):
Inlet Pressure:	Outlet Pressure:	Flow Rate:
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):		

Comments:

Site Report Generated: 6/20/2017 8:09:17 AM

Person In Charge

Inspection By: Melissa Kauffman

Historical 5/17/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Melissa Kauffman

Start Date/Time: 5/17/2013 at 11:44:16 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE POOL

- ENTRANCE TO THE POOL NEEDS TO HAVE A SECURE LATCH
- ALL SAFETY EQUIPMENT IS IN PLACE
- CLARITY IS GOOD
- GREAT RECORD KEEPING
- PLEASE CHECK THAT FLOATING WEIRS ARE IN PLACE TO SLOW DOWN THE FLOW OF WATER TO THE SKIMMERS
- DECK SURFACE IS GOOD
- PIC STATED THAT THE FURNACE FOR THE POOL IS NOT WORKING AND WILL VOLUNTARILY CLOSE THE POOL.

62,000 GAL POOL

FIRE MARSHAL JUST INSPECTED THE PUMP ROOM AND SAID THAT THE ABC CHEMICLE FIRE EXTINGUISHER IS OK FOR PUMP ROOM.

Free Chlorine (0.8-5.0 ppm):	.4	Bromine (3.0-8.0 ppm):		Temperature(F):	76
Combined Chlorine (0-.5 ppm):	.1	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	50	Hardness (175-400 ppm):	270	pH (7.2-7.6):	8.0
Inlet Pressure:		Outlet Pressure:		Flow Rate:	3.4

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

Establishment: 2940018A

Page 10 of 11

Inspection Type: SEMI

Start Date/Time: 5/17/2013 at 11:44:16

TURNOVER IS EVERY 3.4HRS

Site Report Generated: 6/20/2017 8:09:17 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 10

Historical 11/28/2012

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940018A Area: 60
Units: 0
County: 29

PACIFIC CITY - POOL
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Phone: (503) 965-6442 x
Inspector: Annette Pampush

Start Date/Time: 11/28/2012 at 9:35:21 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

ATTEMPTED TO INSPECT, CLOSED EARLY FOR THE SEASON.
POOL IS NOW CLOSING IN OCT, OPEN IN MARCH

Free Chlorine (0.8-5.0 ppm):	Bromine (3.0-8.0 ppm):	Temperature(F):
Combined Chlorine (0-.5 ppm):	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):
Total Alkalinity (80-200 ppm):	Hardness (175-400 ppm):	pH (7.2-7.6):
Inlet Pressure:	Outlet Pressure:	Flow Rate:
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):		

Comments:

Site Report Generated: 6/20/2017 8:09:17 AM

Person In Charge

Inspection By: Annette Pampush