

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - RV
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920133A Area: 31
Units: 305
County: 29

PACIFIC CITY - RV
PO BOX 8000
MONSEY, NY 10952

Phone: (503) 965-6442 x
Inspector: Jaime Craig

Start Date/Time: 11/9/2016 at 3:06:08 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

PERSON IN CHARGE EASILY FOUND
SEMI ANNUAL INSPECTION OF PARK-308 SITES
BACK FLOW PREVENTERS ON MOST SITES- ROW "D" NEEDS SOME AND A FEW OTHER SPOTS.
GREAT FLOW OF TRAFFIC AROUND THE PARK
GARBAGE COLLECTION SITES ARE BEAR PROOF AND GARBAGE PICKED UP ONCE A WEEK IN WINTER-
MORE FREQUENTLY IN THE SUMMER.
SITES ARE EASILY IDENTIFIED-STAFF IS WORKING ON GETTING ROW "I" LABELED
FIRE PITS AND PICNIC TABLES IN GOOD WORKING ORDER
ALL SITES (D, E, I) THAT HAVE SEWER AND RV'S IN PLACE ARE OFF THE GROUND AND SLOPED
CORRECTLY
GOOD SPACING BETWEEN SITES (AT LEAST 10FT)
PARK CLEAN AND WELL MAINTAINED
FIRE EXTINGUISHERS AROUND THE PARK SERVICED JUNE 2016-THANK YOU
RESTROOMS #1 AND #5 ARE CLOSED
RESTROOMS #1,2, 5 HAVE SOME MOLDY SHOWER CURTAINS- PLEASE REPLACE- HOUSEKEEPING SAID
THEY WOULD LOOK INTO IT TODAY
BATHROOM #5 WOMEN'S HAS A BLACK BEETLE INFESTATION- PLEASE CORRECT BEFORE OPENING THIS
BATHROOM TO PUBLIC.

333-031-0008(1)

Violation of OAR 333-031-0008 (1) Insect and rodent control measures are not effective in protecting the public health, preventing a nuisance to the public or accumulations of debris are noted.

RABBITS IN PARK. STAFF AND PATRONS FEEDING RABBITS.

Apply insect and rodent control measures, including maintenance of developed areas, buildings and structures, to be free of accumulating debris, to prevent nuisance to the public and to safeguard the public health.

Establishment: 2920133A

Page 2 of 9

Inspection Type: SEMI

Start Date/Time: 11/9/2016 at 3:06:08

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Person In Charge

Inspection By: Jaime Craig

Page 2

Establishment: 2920133A

Page 3 of 9

Inspection Type: SEMI

Start Date/Time: 3/28/2016 at 3:04:43

Historical 3/28/2016 RECREATIONAL PARK INSPECTION REPORT

Page 3 of 9

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - RV
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920133A Area: 31
Units: 305
County: 29

PACIFIC CITY - RV
PO BOX 8000
MONSEY, NY 10952

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 3/28/2016 at 3:04:43 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

SEMIANNUAL INSPECTION OF RV PARK-

CHECK MIDDLE SECTION OF PARK-
BACKFLOW PREVENTERS ON FAUCETS
GOOD FLOW OF TRAFFIC AROUND PARK
EACH CAMPING VEHICLE IS SPACED OUT BY AT LEAST 10 FEET.
SITES EASILY IDENTIFIABLE
GARBAGE COLLECTION AREAS SAFE
RESTROOMS CLEAN
PIC EASILY FOUND ON SITE

**NO VIOLATIONS- THANKS

Site Report Generated: 6/20/2017 8:10:05 AM

Person In Charge

Inspection By: Mason Lyman

Page 3

Establishment: 2920133A

Page 4 of 9

Inspection Type: SEMI

Start Date/Time: 10/6/2015 at 12:13:04

Historical 10/6/2015 RECREATIONAL PARK INSPECTION REPORT

Page 4 of 9

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

MHC TT, INC DBA PACIFIC CITY

PACIFIC CITY - RV

30000 SANDLAKE RD

CLOVERDALE, OR 97112

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920133A Area: 31

Units: 305

County: 29

PACIFIC CITY - RV

PO BOX 8000

MONSEY, NY 10952

Phone: (503) 965-6442 x

Inspector: Mason Lyman

Start Date/Time: 10/6/2015 at 12:13:04 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

SEMIANNUAL INSPECTION OF RV PARK-

SEWER LINES SLOPED WELL

BACKFLOW PREVENTERS ON FAUCETS

GOOD SPACING OF CAMPING VEHICLES (> 10 FEET)

GOOD FLOW OF TRAFFIC AROUND FACILITY.

RESTROOMS #2 CLEANED AND WELL MAINTAINED

GOOD IDENTIFICATION OF SITES

PIC EASILY FOUND ON SITE.

**NO VIOLATIONS OF PARK- GREAT JOB.

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Person In Charge

Inspection By: Mason Lyman

Page 4

Historical 3/26/2015 RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - RV
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920133A Area: 31
Units: 305
County: 29

PACIFIC CITY - RV
PO BOX 8000
MONSEY, NY 10952

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 3/26/2015 at 3:19:49 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

INSPECTION FACILITY OF RV PARK-

SEWER LINES CONNECTED, NONE LEAKING
GOOD FLOW OF TRAFFIC AROUND PARK, FOR EMERGENCY PERSONNEL.
SITES ARE IDENTIFIED, SECTIONS ARE BEING REPAINTED TO MAKE NUMBERS MORE BOLD AND VISIBLE.
GOOD SEPARATION OF SITES, AT LEAST 10 FEET BETWEEN CAMPING VEHICLES.
GOOD OVERALL PARK CLEANLINESS.
RESTROOM OK/ WELL STOCKED AND CLEANED.

MAINTENANCE IS KEEPING GOOD CARE AROUND PARK, AND MAKING SEVERAL UPGRADES. GOOD UP THE GOOD WORK.

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Historical 8/20/2014 RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - RV
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920133A Area: 31
Units: 305
County: 29

PACIFIC CITY - RV
PO BOX 8000
MONSEY, NY 10952

Phone: (503) 965-6442 x
Inspector: Mason Lyman

Start Date/Time: 8/20/2014 at 1:01:22 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

INSPECTED SECTION F.

- **SITE F27, WATER IS LEAKING FROM THE SPIGOT.
- **RESTROOMS #4, WOMENS- SHARPS CONTAINER IN VERY FULL.
- **DUMP STATION F HAS BROKEN LID ON HOLDING TANK, PLEASE CHECK AND REPAIR.

BACKFLOW PREVENTERS INSTALLED
SLOPED SEWER LINES
WELL MARKED SPOTS EASILY IDENTIFIED
GOOD TRAFFIC FLOW
OUTSIDE BUILDING CLEAN AND WELL MAINTAINED
GARBAGE COLLECTION DONE WELL TO PREVENT CONTAMINATION

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Historical 10/16/2013

RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - RV
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920133A Area: 31
Units: 305
County: 29

PACIFIC CITY - RV
PO BOX 8000
MONSEY, NY 10952

Phone: (503) 965-6442 x
Inspector: Melissa Kauffman

Start Date/Time: 10/16/2013 at 12:01:27 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE RV PARK SECTION A/B ARE CLOSED FOR THE SEASON

SECTION C-D-E-F-G-H-AND L WERE INSPECTED
CAMP SITES ARE EASILY IDENTIFIABLE
WATER SPIGOTS THAT WERE CHECKED HAVE BACK FLOW PREVENTORS
CAMPERS ARE PROPERLY HOOKED UP TO SEWER
DUMP STATIONS ARE IN GOOD REPAIR
RESTROOMS ARE IN GOOD REPAIR
CAMP SITES HAVE PROPER SPACING
CAMP GROUNDS ARE CLEAN AND IN GOOD REPAIR
GARBAGE AND RECYCLING ARE PROPERLY STORED
GOOD DEMONSTRATION OF KNOWLEDGE AND MANAGER CONTROL.

THERE ARE NO VIOLATIONS AT THIS TIME, THANK YOU!

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Establishment: 2920133A

Page 8 of 9

Inspection Type: SEMI

Start Date/Time: 5/17/2013 at 12:02:08

Historical 5/17/2013 RECREATIONAL PARK INSPECTION REPORT

Page 8 of 9

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141

(503) 842-3943

Owner Name:

MHC TT, INC DBA PACIFIC CITY

PACIFIC CITY - RV

30000 SANDLAKE RD

CLOVERDALE, OR 97112

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2920133A Area: 31

Units: 305

County: 29

PACIFIC CITY - RV

PO BOX 8000

MONSEY, NY 10952

Phone: (503) 965-6442 x

Inspector: Melissa Kauffman

Start Date/Time: 5/17/2013 at 12:02:08 PM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

INSPECTION OF THE RV PARK.

ALL SITES ARE CLEARLY MARKED

RESTROOMS ARE IN GOOD CONDITION

RV'S PROPERLY HOOKED UP TO SEWER

MAJORITY OF BACKFLOW PREVENTORS ARE IN PLACE

GARBAGE AND RECYCLING IS GOOD

GROUNDS ARE IN GREAT REPAIR

RESTROOMS ARE IN GOOD REPAIR

THERE ARE NO VIOLATIONS AT THIS TIME THANK YOU!

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 8

Historical 11/28/2012 RECREATIONAL PARK INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
MHC TT, INC DBA PACIFIC CITY
PACIFIC CITY - RV
30000 SANDLAKE RD
CLOVERDALE, OR 97112

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2920133A Area: 31
Units: 305
County: 29

PACIFIC CITY - RV
PO BOX 8000
MONSEY, NY 10952

Phone: (503) 965-6442 x
Inspector: Melissa Kauffman

Start Date/Time: 11/28/2012 at 9:36:14 AM

AN EVALUATION OF SANITATION ON YOUR PREMISES HAS THIS DAY BEEN MADE AND YOU ARE HEREBY NOTIFIED OF THE VIOLATIONS FOUND. VIOLATIONS NOTED ON THIS REPORT MUST BE CORRECTED WITHIN THE TIME LIMIT SPECIFIED.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE RV PARK

CAMP SITES ARE IN GOOD CONDITION
THE MAJORITY OF SITES ARE CLOSED FOR THE SEASON
PICKNIC TABLES ARE IN GOOD REPAIR
GOOD SIGNS FOR MARKING CAMP SITES
RESTROOMS AND SHOWERS ARE IN GOOD REPAIR
OVERALL THE GROUNDS ARE PROPERLY MAINTAINED

333-031-0004(4)

Violation of OAR 333-031-0004 (4) The plumbing system is not in compliance with the applicable provisions of the Oregon Plumbing Specialty Code.

SEVERAL CAMP SITES ARE MISSING BACK FLOW PREVENTORS

Bring the plumbing into compliance with the Oregon Plumbing Specialty Code. Specifically:

PLEASE REPLACE AS NEEDED

Comments:

Site Report Generated: 6/20/2017 8:10:05 AM

Person In Charge

Inspection By: Melissa Kauffman