

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:

ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: REINSP
Inspection Result: COMPLD
Establishment #: 2940009 Area: 60
Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 4/1/2016 at 12:53:03 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

REINSPECTION OF POOL-

FREE CHLORINE OF POOL AT 1.2PPM, INCREASED TO 5.0 PPM DURING INSPECTION.
COMBINED CHLORINE AT 0.2 PPM.

TALKED TO STAFF, AND PROBLEMS ARE BEING ADDRESSED FROM LAST INSPECTION.

| | | |
|---|----------------------------|-----------------|
| Free Chlorine (0.8-5.0 ppm): | Bromine (3.0-8.0 ppm): | Temperature(F): |
| Combined Chlorine (0-.5 ppm): | Cyanuric Acid (0-150 ppm): | Clarity (Y/N): |
| Total Alkalinity (80-200 ppm): | Hardness (175-400 ppm): | pH (7.2-7.6): |
| Inlet Pressure: | Outlet Pressure: | Flow Rate: |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | |

FACILITY IS READY TO OPEN.

Site Report Generated: 6/23/2017 10:19:34 AM

Person In Charge

Inspection By: Mason Lyman

Historical 3/29/2016

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: SEMI
Inspection Result: CONTIN
Establishment #: 2940009 Area: 60

Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 3/29/2016 at 11:20:18 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SEMIANNUAL INSPECTION OF FACILITY-

- SKIMMERS OK
- GATES/DOORS OK
- SHOWER WORKING PHONE AVAILABLE
- DECK SURFACES OK
- SIGNS UP
- LADDERS/STAIRS OK

| | | | | | |
|---|------------|----------------------------|------------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 0.2 | Bromine (3.0-8.0 ppm): | 0.0 | Temperature(F): | 86 |
| Combined Chlorine (0-.5 ppm): | 1.4 | Cyanuric Acid (0-150 ppm): | 60 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 50 | Hardness (175-400 ppm): | 70 | pH (7.2-7.6): | 7.2 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 60 |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | | | | |

333-060-0045(1.2)

VIOLATION OF OAR 333-060-0045 (1) The pool equipment is not operational or appurtenances are in disrepair, creating a health or safety hazard, specifically:

LIFE BUOY WHITE ROBE IS STARTING TO COME APART.

Repair, maintain or replace the equipment so it is operational. Not maintaining the equipment may cause a health and safety hazard.

PLEASE REPLACE.

Establishment: 2940009

Page 3 of 16

Inspection Type: SEMI

Start Date/Time: 3/29/2016 at 11:20:18

333-060-0705(3)(a.1)

VIOLATION OF OAR 333-060-0705 (3)(a) The combined chlorine levels exceed 0.5 ppm.

COMBINED CHLORINE AT 1.4 PPM.

Combined chlorine should be kept as low as possible. The pool should not have a pool smell or cause eye or mucus membrane irritation (trichloramine / nitrogen trichloride), The only way to reduce the irritating nitrogen trichloride at an indoor pool, is

POOL CLOSED. COMBINED CHLORINE MUST GET BELOW 0.5 PPM BEFORE REOPENING. PLEASE CALL OFFICE AT 503-842-3909 WHEN READY.

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Mason Lyman

Page 3

Historical 8/17/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940009 Area: 60

Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 8/17/2015 at 2:56:52 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

- FLOW METER WORKING
- SKIMMERS OK
- GATES/DOORS OK
- STAIRS/ LADDERS OK
- PHONE SIGN UP
- POOL RULES UP
- DECK SURFACE OK
- **NEW POOL CHEMICAL ROOM MADE, FAR MORE SPACE- GREAT

| | | | | | |
|---|------------|----------------------------|------------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | .2 | Bromine (3.0-8.0 ppm): | | Temperature(F): | 88 |
| Combined Chlorine (0-.5 ppm): | 0.0 | Cyanuric Acid (0-150 ppm): | 50 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 60 | Hardness (175-400 ppm): | 450 | pH (7.2-7.6): | 7.6 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 50 |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | | | | |

333-060-0200(1.01)

VIOLATION OF OAR 333-060-0200 (1) The free chlorine residual in the pool is less than 0.8 ppm (0.8 mg/kg) or greater than 5.0 ppm (5 mg / kg). Specifically:

FREE CHLORINE AT 0.2 PPM.

Maintain the free chlorine residual within the range set out in the pool Water Quality Parameters, OAR 333-060-0200 and Table 3; ideal range being 1.0 to 3.0 ppm (1 to 3 mg / kg) free chlorine.

A wading pool must comply with OAR 333-060-0515 (1).

ADD TO MAKE AT LEAST 0.8 PPM.

Establishment: 2940009

Page 5 of 16

Inspection Type: SEMI

Start Date/Time: 8/17/2015 at 2:56:52

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Mason Lyman

Page 5

Historical 2/6/2015 POOL PROGRAM INSPECTION REPORT Page 6 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: REINSP
Inspection Result: COMPLD
Establishment #: 2940009 Area: 60
Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 2/6/2015 at 3:00:31 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

VERY LOW HARDNESS BUT NOT A CLOSURE ISSUE.
PLEASE CORRECT AND GET HARDNESS TO RECOMMENDED LEVELS.

POOL CAN BE AND STAY OPEN AT THE CURRENT TIME.

| | | | | | |
|---|------------|----------------------------|------------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 2.4 | Bromine (3.0-8.0 ppm): | | Temperature(F): | 86 |
| Combined Chlorine (0-.5 ppm): | .3 | Cyanuric Acid (0-150 ppm): | 120 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 170 | Hardness (175-400 ppm): | 60 | pH (7.2-7.6): | 7.6 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 0 |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | | | | |

333-060-0200(1.11)

VIOLATION OF OAR 333-060-0200 (1) The calcium hardness is less than 175 ppm.

HARDNESS AT 60 PPM.

The recommended minimum level of calcium hardness is 175 ppm, per OAR 333-60-200 and Table 3. Most pools need about 250 - 300 ppm of calcium hardness. Low calcium hardness can create corrosive conditions in the pool

Add calcium chloride to increase t

PLEASE CORRECT.

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Historical 1/29/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: SEMI
Inspection Result: CONTIN
Establishment #: 2940009 Area: 60
Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 1/29/2015 at 3:40:36 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

TAKE CHEMISTRY READINGS EVERY 4 HOURS THE POOL IS OPEN.

- SKIMMERS/PIPING OK
- LADDERS DECK SURFACES OK
- GATES/DOORS OK
- SAFETY EQUIPMENT / SIGNS OK
- EMERGENCY PHONE SIGN POSTED- OK

| | | | | | |
|--------------------------------|------------|----------------------------|------------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 2.2 | Bromine (3.0-8.0 ppm): | | Temperature(F): | 86 |
| Combined Chlorine (0-.5 ppm): | .8 | Cyanuric Acid (0-150 ppm): | 140 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 260 | Hardness (175-400 ppm): | 60 | pH (7.2-7.6): | 8.0 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 0 |

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

333-060-0200(1.08)

VIOLATION OF OAR 333-060-0200 (1) The pH is less than 7.0 or greater than 7.8. specifically:

PH AT 8.0

CLOSE THE POOL UNTIL A pH of 7.2 - 7.6 is achieved. Maintain the pH levels within range set out in the spa Water Quality Parameters, OAR 333-062-0165, and Table 1, the ideal being 7.2 - 7.6. See OAR 333-060-0705 (3)(a).

PLEASE CORRECT AND GET WITHIN RANGES BEFORE POOL CAN REOPEN.

333-060-0200(1.09)

VIOLATION OF OAR 333-060-0200 (1) The total alkalinity is less than 80 ppm or greater than 200 ppm. Specifically:

ALKALINITY AT 260 PPM.

Maintain the total alkalinity within the range set out in the pool Water Quality Parameters, OAR 333-060-0200 and Table 3, ideal being approximately 80 - 125 ppm total alkalinity. Most modern pool finishes are durable within this range as long as the cal

PLEASE REDUCE.

Establishment: 2940009

Page 8 of 16

Inspection Type: SEMI

Start Date/Time: 1/29/2015 at 3:40:36

333-060-0200(1.11)

VIOLATION OF OAR 333-060-0200 (1) The calcium hardness is less than 175 ppm.

HARDNESS IS AT 160 PPM.

The recommended minimum level of calcium hardness is 175 ppm, per OAR 333-60-200 and Table 3. Most pools need about 250 - 300 ppm of calcium hardness. Low calcium hardness can create corrosive conditions in the pool

Add calcium chloride to increase t

PLEASE INCREASE TO RECOMMENDED USE.

333-060-0705(1)

VIOLATION OF OAR 333-060-0705(1) The pool meets one or more of the closure criteria. The pool license holder, operator, or responsible supervisor is responsible for closing the pool.

The pool has been closed by the appropriate pool staff, while they eliminate the reason for the pool closure in accordance with OAR 333-060-0705 (3). When the reason for the closure is eliminated, the pool may reopen.
THE POOL STAFF HAS ACTED APPROPRIAT

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Mason Lyman

Page 8

Establishment: 2940009
Inspection Type: REINSP

Page 9 of 16
Start Date/Time: 9/4/2014 at 10:22:54

Historical 9/4/2014

POOL PROGRAM INSPECTION REPORT

Page 9 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: REINSP
Inspection Result: COMPLD
Establishment #: 2940009 Area: 60
Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 9/4/2014 at 10:22:54 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

****CYANURIC ACID LEVEL IS STILL UP. THIS AFFECTS ALKALINITY TRUE READING TO BE CLOSER TO 20 PPM, WHICH IS EXTREMELY LOW.**

COMBINED CHLORINE IS BACK DOWN, AND AT A SAFER LEVEL, THANKS.

EMPLOYEE INFORMED US OF A 6 HOUR TURNOVER OF THE POOL AREA.

****ADD ALKALINITY INCREASER TO RAISE ALKALINITY OF POOL TO CERTAIN LEVELS. TO REACH COMPLIANCE, ADD 45 POUNDS OF SODIUM BICARBONATE TO REACH 80 PPM LEVELS. YOU CAN ADD UP TO 150 POUNDS OF SODIUM BICARBONATE TO BE IN THE MIDDLE OF THE ALKALINITY RANGE.**

****RECOMMEND AUTOMATIC FEEDER FOR DISINFECTION PURPOSES, INSTEAD OF MANUALLY ADDING ALL CHEMICALS.**

| | | | | | |
|---|------------|----------------------------|------------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 1.8 | Bromine (3.0-8.0 ppm): | | Temperature(F): | |
| Combined Chlorine (0-.5 ppm): | 0.4 | Cyanuric Acid (0-150 ppm): | 90 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 50 | Hardness (175-400 ppm): | 190 | pH (7.2-7.6): | 7.1 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 0 |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | | | | |

Establishment: 2940009
Inspection Type: REINSP

Page 10 of 16

Start Date/Time: 9/4/2014 at 10:22:54

333-060-0210(2)

VIOLATION OF OAR 333-060-0210 (2) No telephone, or other acceptable means to reach emergency assistance is accessible, or directions to the telephone are not provided.

NO TELEPHONE IN POOL AREA, OR SIGN DESIGNATING LOCATION OF AN EMERGENCY PHONE.

Provide a telephone that is accessible at all times the pool is open. The telephone must be capable of reaching emergency assistance without the use of coins or cards. Conspicuously post the location of the phone in the pool area.

The phone should b

PLEASE INCLUDE SIGN OF LOCATION OF AN EMERGENCY PHONE THAT IS ACCESSIBLE AT ALL TIMES THE POOL IS OPEN. PROVIDE WITH EMERGENCY INFORMATIN (ADDRESS PHONE AND NAME OF FACILITY).

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Mason Lyman

Page 10

Historical 8/25/2014

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: SEMI
Inspection Result: CONTIN
Establishment #: 2940009 Area: 60
Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Mason Lyman

Start Date/Time: 8/25/2014 at 11:20:32 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

POOL JUST OPENED FOR THE DAY, DECK SURFACE WAS CLEANED AND OUTSIDE PERIMETER IN GOOD REPAIR.
SCREENS HAVE WINDOWS, AND ONLY OPEN A FEW INCHES TO PREVENT SECURITY ISSUES.
LADDERS OK
CLARITY IS GOOD AROUND POOL
SHOWER AVAILABLE FOR PATRONS
RESTROOMS ARE GOOD
POOL LAST SHOCKED SATURDAY NIGHT
RULES LOCATED PROMINENTLY

****COMBINED CHLORINE IS TOO HIGH, PLEASE GET BELOW .5 PPM. CHECK FOR COMBINED CHLORINE OFTEN.
**ALKALINITY SHOULD BE HIGHER, MORE ACCURATE ALKALINITY IN POOL IS 25PPM WITH OTHER METHODS, CONSIDER RAISING.
pH IS LOW, ADD ALKALINE BUFFER TO RAISE Ph TO DESIRED LEVEL.

| | | | | | |
|---|------------|----------------------------|------------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 4.8 | Bromine (3.0-8.0 ppm): | | Temperature(F): | 85 |
| Combined Chlorine (0-.5 ppm): | .8 | Cyanuric Acid (0-150 ppm): | 80 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 50 | Hardness (175-400 ppm): | 200 | pH (7.2-7.6): | 7.0 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 0 |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | | | | |

333-060-0210(2)

VIOLATION OF OAR 333-060-0210 (2) No telephone, or other acceptable means to reach emergency assistance is accessible, or directions to the telephone are not provided.

NO TELEPHONE IN POOL AREA

Provide a telephone that is accessible at all times the pool is open. The telephone must be capable of reaching emergency assistance without the use of coins or cards. Conspicuously post the location of the phone in the pool area.

The phone should b

PROVIDE TELEPHONE IN POOL AREA, OR DIRECTIONS TO LOCAL PHONE AND IMPORTANT ADDRESS AND NUMBERS.

Establishment: 2940009

Page 12 of 16

Inspection Type: SEMI

Start Date/Time: 8/25/2014 at 11:20:32

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Mason Lyman

Page 12

Historical 10/1/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940009 Area: 60

Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Melissa Kauffman

Start Date/Time: 10/1/2013 at 10:50:27 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE POOL

DOOR IS SECURE
DECK EQUIPMENT IS IN GOOD CONDITION
LADDERS AND HANDRAIL ARE TIGHT
DECK IS CLEAN AND DISINFECTED AN DIN GOOD REPAIR
SKIMMERS ARE CLEAR AND IN GOOD CONDITION
SAFETY EQUIPMENT IS PROVIDED
PHONE NEXT TO POOL AT FRONT DESK
TEST KIT AVAILABLE
GOOD RECORD KEEPING
GOOD DEMONSTRATION OF KNOWLEDGE
CLARITY IS GREAT

CHEMICLES ARE BALANCED AND POOL IS IN GREAT REPAIR
TRICHLOR IS USED.

| | | | | | |
|---|------------|----------------------------|-----------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 2.4 | Bromine (3.0-8.0 ppm): | | Temperature(F): | 68 |
| Combined Chlorine (0-.5 ppm): | .1 | Cyanuric Acid (0-150 ppm): | 90 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 80 | Hardness (175-400 ppm): | 60 | pH (7.2-7.6): | 7.0 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 80 |
| ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-): | | | | | |

Establishment: 2940009

Page 14 of 16

Inspection Type: SEMI

Start Date/Time: 10/1/2013 at 10:50:27

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 14

Historical 5/9/2013

POOL PROGRAM INSPECTION REPORT

Page 15 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

ROCKAWAY BEACH RESORT INC
ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97136

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940009 Area: 60

Units: 0
County: 29

ROCKAWAY BEACH RESORT - POOL
615 N PACIFIC
ROCKAWAY, OR 97141

Phone: (503) 355-2191 x
Inspector: Melissa Kauffman

Start Date/Time: 5/9/2013 at 2:10:24 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE POOL.

THE POOL IS ABOUT 11,000GAL
OPERATOR USES TRICHLOR CHLORINE
NEW FILTERS HAVE BEEN INSTALLED
NEW FLOW METERS ARE AVAILABLE
WEIRS ARE IN PLACE
SKIMMER LOOKS GOOD
ENCLOSURE IS GOOD
CLARITY IS GREAT
POOL SAFETY EQUIPMENT IS PROVIDED

TURNOVER IS EVERY 3 HOURS FOR POOL
GOOD RECORD KEEPING AND DEMONSTRATION OF KNOWLEDGE.

| | | | | | |
|--------------------------------|------------|----------------------------|-----------|-----------------|------------|
| Free Chlorine (0.8-5.0 ppm): | 1.6 | Bromine (3.0-8.0 ppm): | | Temperature(F): | 86 |
| Combined Chlorine (0-.5 ppm): | .1 | Cyanuric Acid (0-150 ppm): | 0 | Clarity (Y/N): | Y |
| Total Alkalinity (80-200 ppm): | 60 | Hardness (175-400 ppm): | 80 | pH (7.2-7.6): | 7.0 |
| Inlet Pressure: | | Outlet Pressure: | | Flow Rate: | 60 |

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

Establishment: 2940009

Page 16 of 16

Inspection Type: SEMI

Start Date/Time: 5/9/2013 at 2:10:24 PM

Comments:

Site Report Generated: 6/23/2017 10:19:35 AM

Person In Charge

Inspection By: Melissa Kauffman

Page 16