

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943

Owner Name:  
SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60  
Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Annette Pampush

Start Date/Time: 1/25/2017 at 1:38:06 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

Comments:

Free Chlorine (0.8-5.0 ppm):	<b>2.4</b>	Bromine (3.0-8.0 ppm):	Temperature(F):	<b>82</b>
Combined Chlorine (0-.5 ppm):	<b>.4</b>	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>90</b>	Hardness (175-400 ppm):	pH (7.2-7.6):	<b>7.4</b>
Inlet Pressure:	<b>120</b>	Outlet Pressure:	Flow Rate:	<b>0</b>
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):	<b>760</b>			

333-060-0060(1.1)

VIOLATION OF OAR 333-060-0060 (1) The pool has sharp edges or protrusions.

**TILES BROKEN OR MISSING AROUND EDGE OF POOL**

Remove or repair sharp edges or protrusions. Specifically:

333-060-0080(9)

VIOLATION OF OAR 333-060-0080 (9) The pool ladder or handrail is not securely mounted.

**HANDRAIL ON SOUTH END A LITTLE LOOSE**

Securely mount all ladders and handrails. Specifically:

333-060-0215(2)(a)

VIOLATION OF OAR 333-060-0215 (2)(a) The pool-use rules, required to be posted on the pool rule sign at pools without lifeguards, are not posted or are incomplete.

**THE SIGN IS NOT EASILY VISIBLE , VERY SMALL FONT AT ENTRANCE**

"Pools that do not provide lifeguards, must post pool rules signs with the rules included as required by OAR 333-060-0215 (2)(a).

-"NO LIFEGUARD ON DUTY" [In letters at least 4 inches (100 mm).]

-"BRING A FRIEND - Do not swim alone."

-"CHILDREN U

**SIGN LETTERS SHOULD BE 4 INCHES**

Establishment: 2940026

Page 2 of 16

Inspection Type: SEMI

Start Date/Time: 1/25/2017 at 1:38:06

Comments:

---

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Annette Pampush

Page 2

Establishment: 2940026  
Inspection Type: REINSP

Page 3 of 16  
Start Date/Time: 4/1/2016 at 10:21:30

**Historical 4/1/2016**

**POOL PROGRAM INSPECTION REPORT**

Page 3 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:  
SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: REINSP  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60  
Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Mason Lyman

Start Date/Time: 4/1/2016 at 10:21:30 AM

---

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

REINSPECTION OF FACILITY-

FREE CHLORINE AT 3.8  
COMBINED CHLORINE AT 0,0.  
PH AT 7.5.

READY TO OPEN.

Free Chlorine (0.8-5.0 ppm):	Bromine (3.0-8.0 ppm):	Temperature(F):
Combined Chlorine (0-.5 ppm):	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):
Total Alkalinity (80-200 ppm):	Hardness (175-400 ppm):	pH (7.2-7.6):
Inlet Pressure:	Outlet Pressure:	Flow Rate:
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):		

Comments:

---

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Mason Lyman

Page 3

**Historical 3/29/2016**

**POOL PROGRAM INSPECTION REPORT**

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:

SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: CONTIN  
Establishment #: 2940026 Area: 60

Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Mason Lyman

Start Date/Time: 3/29/2016 at 3:36:10 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SKIMMERS OK  
GATES/DOORS OK  
DECK SURFACES OK  
STAIRS OK- TRY TO TIGHTEN THE HANDRAILS.  
GOOD TESTING FREQUENCY  
GOOD RECORD KEEPING.

Free Chlorine (0.8-5.0 ppm):	<b>0.0</b>	Bromine (3.0-8.0 ppm):		Temperature(F):	<b>82</b>
Combined Chlorine (0-.5 ppm):	<b>0.6</b>	Cyanuric Acid (0-150 ppm):	<b>50</b>	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>100</b>	Hardness (175-400 ppm):	<b>220</b>	pH (7.2-7.6):	<b>7.7</b>
Inlet Pressure:		Outlet Pressure:		Flow Rate:	<b>0</b>

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

333-060-0705(3)(a)

VIOLATION OF OAR 333-060-0705 (3)(a) The disinfectant level does not meet the parameters in OAR 333-060-0200(1), OAR 333-060-0515(1) or items (a) thru (c) of Table 3.

**POOL FREE CHLORINE AT 0.0 PPM.**

The minimum residual for free chlorine is 0.8 ppm and the maximum is 5 ppm for pools, and 2.0 ppm to 5.0 ppm, minimum to maximum for wading pools and spray pools. The ideal ORP level is 750 mv. or higher. Consistent maintenance of an ORP of 750 mv. or h

**SHOCK POOL TONIGHT, AND KEEP FREE CHLORINE ABOVE 0.8 PPM. WHEN READY, REOPEN, AND CALL OFFICE AT 503-842-3909.**

Comments:

Site Report Generated: 6/23/2017 3:54:17 PM

**Historical 7/27/2015**

**POOL PROGRAM INSPECTION REPORT**

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:

SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60  
Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Mason Lyman

Start Date/Time: 7/27/2015 at 11:15:09 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

INSPECTION OF POOL-

SKIMMERS OK  
POOL ENCLOSURE/DOORS/WINDOWS OK  
GATES/LADDERS/STAIRS OK  
GOOD SIGNAGE AROUND POOL  
DECK SURFACE OK, FEW WATER SPOTS POOLING AROUND DRAINS, BUT NOT DOWN DRAINS.

Free Chlorine (0.8-5.0 ppm):	<b>7.6</b>	Bromine (3.0-8.0 ppm):		Temperature(F):	<b>83</b>
Combined Chlorine (0-.5 ppm):	<b>0.4</b>	Cyanuric Acid (0-150 ppm):	<b>200</b>	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>120</b>	Hardness (175-400 ppm):	<b>150</b>	pH (7.2-7.6):	<b>7.1</b>
Inlet Pressure:		Outlet Pressure:		Flow Rate:	<b>0</b>

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

333-060-0110(4)(a)

VIOLATION OF OAR 333-060-0110 (4)(a) The deck surface is not constructed of concrete, non-slip tile, or a water impervious material with a slip-resistant and easily cleanable surface.

**TILES MISSING ALONG EDGE OF POOL DECK**

Provide a deck with an approved, non-slip, easy to clean and water impervious surface.

**PLEASE REPAIR TO MAKE SAFE ENVIRONMENT FOR PATRONS.**

333-060-0155(1)

VIOLATION OF OAR 333-060-0155 (1) A flow meter is not provided, not properly installed, not located or is not functioning.

**FLOW METER NOT WORKING AT POOL.**

Install and maintain a flow meter in the recirculation piping, measuring flow in gallons per minute. Mount the flow meter per manufacturer's recommendation in a location where it can be easily read, and on a length of straight pipe.

**RECENTLY INSTALLED FLOW METER, NOT WORKING. PLEASE CORRECT TO ALLOW TO CALCULATE TURNOVER OF POOL WATER.**

VIOLATION OF OAR 333-060-0705 (3)(a) The cyanuric acid levels exceed 150 ppm.

Cyanuric acid is an ingredient of stabilized chlorine products. It can also be added as straight cyanuric acid.

**CYA WELL ABOVE 200 PPM.**

Cyanuric acid (CYA) is a chlorine stabilizer against UV light degradation of the chlorine. The protection of the stabilizer lowers the activity of the free chlorine. At high levels of cyanuric acid, chlorine has lost much of its disinfecting power. CYA

**SHILO INN IS PUTTING A NEW CHLORINE AUTO FEED SYSTEM, GOING TO CAL  
HYPO FROM DICHLOR. HAVE SYSTEM ON SITE, PIC SAID WILL BE INSTALLING  
WITHIN THE MONTH.**

Comments:

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Mason Lyman

Page 6

**Historical 2/2/2015 POOL PROGRAM INSPECTION REPORT** Page 7 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:  
SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60  
Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Mason Lyman  
Start Date/Time: 2/2/2015 at 1:10:18 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

- SKIMMERS OK
- LADDERS/STAIRS OK
- DECK SURFACES OK
- SAFETY EQUIPMENT OK
- PHONE INSTALLED
- SIGNS OK
- RECORDS OK
- MAIN DRAIN OK

AIR TEMPERATURE OF POOL AREA IS GREAT.

\*\*TALKED TO PIC AND POOL OPERATOR ABOUT CHLORINE OPTIONS TO REDUCE CYANURIC ACID LEVELS IN THE FUTURE.

\*\*DATE CHEMICAL BOTTLES.

\*\*CONSIDER BACKWASHING AT AN INCREASE OF 8-10 PSI, INSTEAD OF ONLY 2 PSI TO EXTEND LIFE OF SAND FILTERS AND INCREASE EFFICIENCY OF SAND FILTRATION.

Free Chlorine (0.8-5.0 ppm):	<b>7.8</b>	Bromine (3.0-8.0 ppm):		Temperature(F):	<b>83</b>
Combined Chlorine (0-.5 ppm):	<b>0.</b>	Cyanuric Acid (0-150 ppm):	<b>300</b>	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>110</b>	Hardness (175-400 ppm):	<b>120</b>	pH (7.2-7.6):	<b>7.2</b>
Inlet Pressure:		Outlet Pressure:		Flow Rate:	<b>40</b>
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

333-060-0155(1)

VIOLATION OF OAR 333-060-0155 (1) A flow meter is not provided, not properly installed, not located or is not functioning.

**FLOW METER NOT WORKING FOR POOL TURNOVER RATE.**

Install and maintain a flow meter in the recirculation piping, measuring flow in gallons per minute. Mount the flow meter per manufacturer's recommendation in a location where it can be easily read, and on a length of straight pipe.

**PLEASE CORRECT.**

333-060-0200(1.11)

VIOLATION OF OAR 333-060-0200 (1) The calcium hardness is less than 175 ppm.

**CALCIUM HARDNESS AT 110 PPM**

The recommended minimum level of calcium hardness is 175 ppm, per OAR 333-60-200 and Table 3. Most pools need about 250 - 300 ppm of calcium hardness. Low calcium hardness can create corrosive conditions in the pool

Add calcium chloride to increase t

**PLEASE INCREASE TO RECOMMENDED LEVELS.**

333-060-0705(3)(a.3)

VIOLATION OF OAR 333-060-0705 (3)(a) The cyanuric acid levels exceed 150 ppm.

Cyanuric acid is an ingredient of stabilized chlorine products. It can also be added as straight cyanuric acid.

**CYANURIC ACID LEVELS AT 300 PPM.**

Cyanuric acid (CYA) is a chlorine stabilizer against UV light degradation of the chlorine. The protection of the stabilizer lowers the activity of the free chlorine. At high levels of cyanuric acid, chlorine has lost much of its disinfecting power. CYA

**PLEASE REDUCE.**

Comments:

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Mason Lyman

Page 8



Establishment: 2940026

Inspection Type: SEMI

Start Date/Time: 8/19/2014 at 9:24:08

**Historical 8/19/2014**

**POOL PROGRAM INSPECTION REPORT**

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:

SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60

Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Mason Lyman

Start Date/Time: 8/19/2014 at 9:24:08 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SKIMMERS ON AND WORKING  
LADDERS OK  
GATER/DOORS OK  
SAFETY EQUIPMENT AND SIGNS OK  
GOOD RECORDS.  
CLEAN SMOOTH DECK SURFACE

Free Chlorine (0.8-5.0 ppm):	<b>6.</b>	Bromine (3.0-8.0 ppm):	Temperature(F):	<b>85</b>	
Combined Chlorine (0-.5 ppm):	<b>.4</b>	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	<b>Y</b>	
Total Alkalinity (80-200 ppm):	<b>130</b>	Hardness (175-400 ppm):	<b>180</b>	pH (7.2-7.6):	<b>7.1</b>
Inlet Pressure:		Outlet Pressure:	Flow Rate:	<b>10</b>	

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

Comments:

Site Report Generated: 6/23/2017 3:54:17 PM

Person In Charge

Inspection By: Mason Lyman

**Historical 10/1/2013**

**POOL PROGRAM INSPECTION REPORT**

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:

SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60

Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Melissa Kauffman

Start Date/Time: 10/1/2013 at 2:07:52 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE POOL

CLARITY IS GOOD  
POOL TEMP 88F  
FREE CHLORINE 9.4  
COMBINED 0  
PH 7  
TOTAL ALKALINITY 70  
CALCIUM HARDNESS 170  
CYANURIC ACID 90

PIC DRAINS POOL WATER TO CONTROL CYA LEVELS  
PHONE LOCATED ON DECK  
DOORS ARE SECURE  
DECK SURFACE IS GOOD  
EQUIPMENT ON DECK IN GOOD REPAIR  
SKIMMERS ARE GOOD -NEW BLUE WEIR FOR POOL INSIDE SKIMMER  
SAFETY EQUIPMENT PROVIDED  
FLOW METER NOT WORKING AT THIS TIME.

OVERALL POOL MANAGER HAS GOOD KNOWLEDGE

Free Chlorine (0.8-5.0 ppm):	<b>9.4</b>	Bromine (3.0-8.0 ppm):		Temperature(F):	<b>88</b>
Combined Chlorine (0-.5 ppm):	<b>0.</b>	Cyanuric Acid (0-150 ppm):	<b>90</b>	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>70</b>	Hardness (175-400 ppm):	<b>170</b>	pH (7.2-7.6):	<b>7.</b>
Inlet Pressure:		Outlet Pressure:		Flow Rate:	<b>0</b>
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

Establishment: 2940026

Page 11 of 16

Inspection Type: SEMI

Start Date/Time: 10/1/2013 at 2:07:52

\*PLEASE REPAIR FLOW METER  
14880 GAL POOL

---

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Melissa Kauffman

Page 11

**Historical 5/3/2013 POOL PROGRAM INSPECTION REPORT** Page 12 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:  
SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: REINSP  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60  
Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Melissa Kauffman

Start Date/Time: 5/3/2013 at 8:00:47 AM

---

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

Shilo Pool was reopened on Friday, May 3rd 2013.

The pool and Spa have new water, all chemistry is starting from scratch. Sine Trichlor is still being used the pool cyanuric acid levels are at 30ppm and Spa cyanuric acid is not present.

A Shilo pool maintenance man who travels around was adjusting the chemicals to be in range and discussing with the corporate office to purchase a non trichlor or dichlor type product for chlorine.

All previous closure violations have been addressed for the pool and the spa therefor once the new water is adjusted to proper temperatures they will reopen for the weekend.

Free Chlorine (0.8-5.0 ppm):	Bromine (3.0-8.0 ppm):	Temperature(F):
Combined Chlorine (0-.5 ppm):	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):
Total Alkalinity (80-200 ppm):	Hardness (175-400 ppm):	pH (7.2-7.6):
Inlet Pressure:	Outlet Pressure:	Flow Rate:
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):		

Establishment: 2940026  
Inspection Type: REINSP

Page 13 of 16  
Start Date/Time: 5/3/2013 at 8:00:47 AM

---

Comments:

---

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Melissa Kauffman

Page 13

**Historical 5/2/2013**

**POOL PROGRAM INSPECTION REPORT**

Page 14 of 16

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:

SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: CONTIN  
Establishment #: 2940026 Area: 60  
Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Melissa Kauffman

Start Date/Time: 5/2/2013 at 1:08:15 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

CHLORINE USED IS TRICHLOR AND SODIUM DICHLORIDE.

CHLORINE 4.4 PPM

COMBINE CHLORINE .4PPM (VERY HIGH) GOAL IS OPPM. - STAFF DOES NOT TEST FOR COMBINED CHLORINE, PLEASE TEST.

CYANURIC ACID IS TOO HIGH TO MEASURE.

PH 7.2PPM

CALCIUM HARDNESS 210PPM

TEMPERATURE 84F

MAIN DRAIN GRATE IS GOOD

RECORD KEEPING NEEDS TO INCLUDE TESTING FOR CYANURIC ACID AND COMBINED CHLORINE.

ALSO POOL CHEMISTRY NEEDS TO BE MEASURED BEFORE OPENING.

GOOD SIGNS FOR SAFETY

POOL PHONE AVAILABLE

SKIMMERS ARE IN GOOD CONDITION

CLARITY IS GOOD

ENCLOSURES ARE GOOD

PERSONEL PROTECTIVE EQUIPMENT IS AVAILABLE

TURNOVER RATE FOR 14,880GAL POOL = 8.2 HOURS

Free Chlorine (0.8-5.0 ppm):	<b>2.</b>	Bromine (3.0-8.0 ppm):	Temperature(F):	<b>85</b>
Combined Chlorine (0-.5 ppm):	<b>.4</b>	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>48</b>	Hardness (175-400 ppm):	pH (7.2-7.6):	<b>.7</b>
Inlet Pressure:		Outlet Pressure:	Flow Rate:	<b>5.3</b>
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):				

PLEASE TAKE POOL CHEMISTRY BEFORE OPENING.

TRICHLOROISOCYANURIC ACID AND DICHLOROCYANURIC ACID ARE RECOMMENDED FOR OUTDOOR POOLS ONLY. ONCE THE CHLORINE PORTION OF THESE PRODUCTS ARE DEPLETED THE CYANURIC ACID REMAINS AND WILL ONLY INCREASE IN CONCENTRATION AS MORE DISINFECTANT IS ADDED TO THE WATER.

CYANURIC ACID HAS NO DISINFECTANT PROPERTIES AND SHOULD BE MAINTAINED BETWEEN 30-50PPM.

CYANURIC ACID THAT IS PRESENT IN HIGH CONCENTRATIONS REQUIRES MORE CHLORINE AND LONGER CONTACT TIMES TO KILL RECREATIONAL WATER ILLNESSES SUCH AS CRYPTOSPORIDIUM.

DUE TO HIGH LEVELS OF CYANURIC ACID THE POOL WILL BE CLOSED UNTIL LEVELS ARE BELOW 150PPM

PLEASE CONTACT MELISSA AT (503-842-3909) BEFORE OPENING THE POOL.

---

Site Report Generated: 6/23/2017 3:54:17 PM

---

Person In Charge

Inspection By: Melissa Kauffman

Page 15

**Historical 9/11/2012**

**POOL PROGRAM INSPECTION REPORT**

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141  
(503) 842-3943**

Owner Name:

SHILO INN TILLAMOOK, LLC  
SHILO INN TILLAMOOK - POOL  
2515 MAIN AVE N  
TILLAMOOK, OR 97141

Inspection Type: SEMI  
Inspection Result: COMPLD  
Establishment #: 2940026 Area: 60

Units: 0  
County: 29

SHILO INN TILLAMOOK - POOL  
11600 SW SHILO LN  
PORTLAND, OR 97225

Phone: (503) 842-7971 x  
Inspector: Melissa Kauffman

Start Date/Time: 9/11/2012 at 12:53:46 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE POOL

- CLARITY IS GOOD
- LADDERS ARE SECURE
- GOOD SIGNS FOR SAFETY
- EMERGENCY PHONE AND ADDRESS LOCATED IN POOL AREA
- GATES AND DOORS ARE SECURE
- POOL SURFACE IS OK
- GOOD RECORD KEEPING

Free Chlorine (0.8-5.0 ppm):	<b>2.6</b>	Bromine (3.0-8.0 ppm):	Temperature(F):	<b>96</b>
Combined Chlorine (0-.5 ppm):	<b>.4</b>	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	<b>Y</b>
Total Alkalinity (80-200 ppm):	<b>220</b>	Hardness (175-400 ppm):	pH (7.2-7.6):	<b>7.4</b>
Inlet Pressure:		Outlet Pressure:	Flow Rate:	<b>0</b>
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):				

Comments:

Site Report Generated: 6/23/2017 3:54:17 PM