

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:

WON KIM

SILVER SANDS MOTEL - POOL

215 PACIFIC ST

ROCKAWAY, OR 97136

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2940011A Area: 60

Units: 0

County: 29

SILVER SANDS MOTEL - POOL

PO BOX 1055

MANZANITA, OR 97130

Phone: (503) 355-2206 x

Inspector: Jaime Craig

Start Date/Time: 1/26/2017 at 12:28:15 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

**REQUIRE CALCIUM HARDNESS TESTING ONCE A WEEK.

LADDERS AND HANDRAILS

SIGNAGE GOOD

SAFETY EQUIPMENT AVAILABLE

CLARITY-GOOD

POOL RECORDS ALL OK

Free Chlorine (0.8-5.0 ppm):	4.0	Bromine (3.0-8.0 ppm):	Temperature(F):	90	
Combined Chlorine (0-.5 ppm):	.6	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y	
Total Alkalinity (80-200 ppm):	90	Hardness (175-400 ppm):	450	pH (7.2-7.6):	7.4
Inlet Pressure:		Outlet Pressure:	Flow Rate:	.2	
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

Comments:

Site Report Generated: 6/23/2017 12:35:06 PM

Person In Charge

Inspection By: Jaime Craig

Historical 3/30/2016

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

WON KIM

SILVER SANDS MOTEL - POOL

215 PACIFIC ST

ROCKAWAY, OR 97136

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2940011A Area: 60

Units: 0

County: 29

SILVER SANDS MOTEL - POOL

PO BOX 1055

MANZANITA, OR 97130

Phone: (503) 355-2206 x

Inspector: Mason Lyman

Start Date/Time: 3/30/2016 at 12:29:51 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SEMIANNUAL INSPECTION OF FACILITY-

SKIMMERS OK

GATES/DOORS OK

LADDERS/STAIRS OK

CLARITY IS OK

OUTER OF BUILDING OK

NEW PAINT ON INSIDE OF NATATORIUM

DECK SURFACE OK

Free Chlorine (0.8-5.0 ppm):	1.8	Bromine (3.0-8.0 ppm):		Temperature(F):	88
Combined Chlorine (0-.5 ppm):	0.1	Cyanuric Acid (0-150 ppm):	200	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	70	Hardness (175-400 ppm):	250	pH (7.2-7.6):	7.0
Inlet Pressure:		Outlet Pressure:		Flow Rate:	70
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

333-060-0205(2)

VIOLATION OF OAR 333-060-0205 (2) The records pertaining to pool operation, testing and maintenance are not being kept, have incomplete information or are not available for inspection.

NO RECORD OF WHAT AND HOW MUCH OF EACH CHEMICAL IS PUT IN POOL.

Keep and provide daily records pertaining to the operation, testing and maintenance of the pool. The records must include the results of required water testing, date and time of filter cleaning, dates that the pool was emptied or cleaned, period of recirc

PLEASE RECORD ON RECORD SHEETS. PLEASE MARK EVERY TEST YOU DO ON RECORD SHEET. KEEP FOR 2 YEARS.

Establishment: 2940011A

Page 3 of 6

Inspection Type: SEMI

Start Date/Time: 3/30/2016 at 12:29:51

**CYANURIC ACID AT 200 PPM- RECOMMEND SWITCHING CHLORINE PRODUCTS TO REDUCE LEVELS FOR THE LONG TERM.

Site Report Generated: 6/23/2017 12:35:07 PM

Person In Charge

Inspection By: Mason Lyman

Page 3

Historical 8/18/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

WON KIM

SILVER SANDS MOTEL - POOL

215 PACIFIC ST

ROCKAWAY, OR 97136

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2940011A Area: 60

Units: 0

County: 29

SILVER SANDS MOTEL - POOL

PO BOX 1055

MANZANITA, OR 97130

Phone: (503) 355-2206 x

Inspector: Mason Lyman

Start Date/Time: 8/18/2015 at 3:15:29 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

15,000 GALLON POOL

GOOD TURNOVER- 48 GPM.

NO LEAKS DETECTED IN SYSTEM

DECK SURFACE OK

NEW PAINT ALONG WALLS ON FACILITY

PHONE SIGN UP IN FACILITY

****PIC SAID THEY ARE PLANNING ON SWITCHING FROM TRICHLOR, TO CAL HYPO WITHIN THE NEXT 6 MONTHS.**

Free Chlorine (0.8-5.0 ppm):	7.6	Bromine (3.0-8.0 ppm):		Temperature(F):	89
Combined Chlorine (0-.5 ppm):	0.0	Cyanuric Acid (0-150 ppm):	400	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	60	Hardness (175-400 ppm):	330	pH (7.2-7.6):	7.0
Inlet Pressure:		Outlet Pressure:		Flow Rate:	48
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

333-060-0200(1.14)

VIOLATION OF OAR 333-060-0200 (1) The pool water clarity is cloudy, all or part of the pool bottom is difficult to see clearly. Specifically:

POOL IS CLOUDY, AND MAIN DRAIN IS BARELY VISIBLE.

Maintain the water clarity within range set out in the pool Water Quality Parameters, OAR 333-060-0200 and Table 3. The pool bottom at the deepest point and the main drain should be easily visible from the pool deck.

KEEP AN EYE ON VISIBILITY, AND RECORD IN RECORD SHEET.

333-060-0200(3)(4)

VIOLATION OF OAR 333-060-0200 (3) & (4) The pool water quality parameters are not tested at the required frequencies or are not recorded.

ONLY RECORDING CHLORINE TEST ONCE A DAY.A DAY, EVEN THOUGH PIC SAID THEY ARE TESTING SEVERAL TIMES

Complete and record the required pool water tests at the minimum frequencies as described in OAR 333-060-0200 (3)(a) to (3)(j), or as required by the Division or local public health authority.

PLEASE TEST AS OFTEN AS FORM GIVEN. RECORDS TEST RESULTS IN ONE LOCATION.

Establishment: 2940011A

Page 5 of 6

Inspection Type: SEMI

Start Date/Time: 8/18/2015 at 3:15:29

Comments:

Site Report Generated: 6/23/2017 12:35:07 PM

Person In Charge

Inspection By: Mason Lyman

Page 5

Historical 2/5/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

WON KIM

SILVER SANDS MOTEL - POOL

215 PACIFIC ST

ROCKAWAY, OR 97136

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2940011A Area: 60

Units: 0

County: 29

SILVER SANDS MOTEL - POOL

PO BOX 1055

MANZANITA, OR 97130

Phone: (503) 355-2206 x

Inspector: Mason Lyman

Start Date/Time: 2/5/2015 at 3:58:23 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

POOL DECK/SAFETY EQUIPMENT OK

PHONE SIGN IS COMING THIS WEEK

LADDERS/STAIRS OK

TALKED TO PIC ABOUT POOL CHEMISTRY AND UPCOMING CLASS.

POOL IN FULL COMPLIANCE.

Free Chlorine (0.8-5.0 ppm):	4.6	Bromine (3.0-8.0 ppm):		Temperature(F):	86
Combined Chlorine (0-.5 ppm):	.2	Cyanuric Acid (0-150 ppm):	140	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	90	Hardness (175-400 ppm):	270	pH (7.2-7.6):	7.6
Inlet Pressure:		Outlet Pressure:		Flow Rate:	0
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

Comments:

Site Report Generated: 6/23/2017 12:35:07 PM

Person In Charge

Inspection By: Mason Lyman