

Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943

Owner Name:
TILLAMOOK COUNTY FAMILY YMCA
TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940040 Area: 60
Units: 0
County: 29

TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Phone: (503) 842-9622 x
Inspector: Annette Pampush

Start Date/Time: 1/24/2017 at 2:28:18 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THIS POOL IS ADJACENT TO PRIMARY YMCA POOL. SAME VIOLATIONS ARE FOR BOTH POOLS, REFER TO THOSE ON THAT REPORT

Free Chlorine (0.8-5.0 ppm):	2.4	Bromine (3.0-8.0 ppm):	Temperature(F):	82	
Combined Chlorine (0-.5 ppm):	0.6	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y	
Total Alkalinity (80-200 ppm):	130	Hardness (175-400 ppm):	130	pH (7.2-7.6):	
Inlet Pressure:		Outlet Pressure:		Flow Rate:	130
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):	690				

Comments:

Site Report Generated: 6/23/2017 3:45:17 PM

Person In Charge

Inspection By: Annette Pampush

Historical 3/30/2016

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
TILLAMOOK COUNTY FAMILY YMCA
TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940040 Area: 60
Units: 0
County: 29

TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Phone: (503) 842-9622 x
Inspector: Mason Lyman

Start Date/Time: 3/30/2016 at 4:20:22 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

SEMIANNUAL INSPECTION OF LEISURE POOL-

SKIMMERS OK
GATES/DOORS OK
SAFETY EQUIPMENT PRESENT
BLOOD BORNE PATHOGEN KIT PRESENT
LIFEGUARD ON DUTY AT ALL TIMES
OXYGEN MASK, EQUIPMENT PRESENT
GOOD RECORD KEEPING
GOOD TESTING FREQUENCY.
NO LEAKS, EQUIPMENT IN GOOD REPAIR.
HOLES COVERED IN CHEMICAL ROOM.

Free Chlorine (0.8-5.0 ppm):	4.2	Bromine (3.0-8.0 ppm):		Temperature(F):	87
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	140	Hardness (175-400 ppm):	240	pH (7.2-7.6):	7.4
Inlet Pressure:		Outlet Pressure:		Flow Rate:	0
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):		720			

Establishment: 2940040

Page 3 of 10

Inspection Type: SEMI

Start Date/Time: 3/30/2016 at 4:20:22

**NO VIOLATIONS- THANKS

Site Report Generated: 6/23/2017 3:45:18 PM

Person In Charge

Inspection By: Mason Lyman

Page 3

Historical 9/30/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
TILLAMOOK COUNTY FAMILY YMCA
TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940040 Area: 60
Units: 0
County: 29

TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Phone: (503) 842-9622 x
Inspector: Mason Lyman

Start Date/Time: 9/30/2015 at 3:29:04 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

- SKIMMERS OK
- GATES/LADDERS OK
- GOOD CLEANING SCHEDULE WITH ORP PROBES.
- SAFETY EQUIPMENT OK
- BLOODBORNE PATHOGEN KIT AVAILABLE
- ADA EQUIPMENT IN FACILITY
- RESTROOM CLEAN/ STOCKED

Free Chlorine (0.8-5.0 ppm):	1.8	Bromine (3.0-8.0 ppm):		Temperature(F):	88
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	100	Hardness (175-400 ppm):	210	pH (7.2-7.6):	7.5
Inlet Pressure:		Outlet Pressure:		Flow Rate:	320
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

333-060-0200(3)(4)

VIOLATION OF OAR 333-060-0200 (3) & (4) The pool water quality parameters are not tested at the required frequencies or are not recorded.

FACILITY TESTING COMBINED CHLORINE ONLY ONCE A DAY.

Complete and record the required pool water tests at the minimum frequencies as described in OAR 333-060-0200 (3)(a) to (3)(j), or as required by the Division or local public health authority.

PLEASE TEST COMBINED CHLORINE AS OFTEN AS FREE CHLORINE. INCLUDE SPACE FOR RECORDING COMBINED CHLORINE ON TEST SHEET AT LIFE GAARD STATIONS AND IN POOL CHEMICAL ROOM. GAVE PIC FORM TO ALLOW SPACE FOR ADDITIONAL MEASUREMENTS.

Establishment: 2940040

Page 5 of 10

Inspection Type: SEMI

Start Date/Time: 9/30/2015 at 3:29:04

**CONTINUE TRAINING OF STAFF WITH OXYGEN TANK, AED, FECAL ACCIDENT RESPONSE, AND HOW TO USE FIRST AID KIT.

**RECOMMEND REPLACING MISSING TILES IN FLOORS IN RESTROOM TO REDUCE CHANCE OF TRIPS AND FALLS.

Site Report Generated: 6/23/2017 3:45:18 PM

Person In Charge

Inspection By: Mason Lyman

Page 5

Historical 2/20/2015

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
TILLAMOOK COUNTY FAMILY YMCA
TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940040 Area: 60
Units: 0
County: 29

TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Phone: (503) 842-9622 x
Inspector: Mason Lyman

Start Date/Time: 2/20/2015 at 3:49:02 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

Comments:

Free Chlorine (0.8-5.0 ppm): **2.2** Bromine (3.0-8.0 ppm): Temperature(F): **87**
Combined Chlorine (0-.5 ppm): **.4** Cyanuric Acid (0-150 ppm): **0** Clarity (Y/N): **Y**
Total Alkalinity (80-200 ppm): **100** Hardness (175-400 ppm): **260** pH (7.2-7.6): **7.6**
Inlet Pressure: Outlet Pressure: Flow Rate: **0**
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

SATURATION INDEX OF WARM POOL AT 0.1. WELL BALANCED WATER.
SKIMMERS/LADDERS/STAIRS OK
GOOD TURNOVER OF POOL
FILTERS ARE CLEAN AND ON GOOD BACKWASH CYCLE.
PIC IS KNOWLEDGEABLE OF POOL RULES
NEW FIRST AID KITS AT LIFEGUARD STATIONS.
**RECORD KEEPING NEEDS TO INCLUDE PH READING EACH DAY.
**PLEASE CONSIDER SUPERCHLORINATING POOL SOON TO AVOID BUILDUP OF COMBINED CHLORINE.

Site Report Generated: 6/23/2017 3:45:18 PM

Establishment: 2940040

Inspection Type: SEMI

Start Date/Time: 9/2/2014 at 11:08:55

Historical 9/2/2014

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:

TILLAMOOK COUNTY FAMILY YMCA

TILLAMOOK YMCA POOL 2

610 STILLWELL

TILLAMOOK, OR 97141

Inspection Type: SEMI

Inspection Result: COMPLD

Establishment #: 2940040 Area: 60

Units: 0

County: 29

TILLAMOOK YMCA POOL 2

610 STILLWELL

TILLAMOOK, OR 97141

Phone: (503) 842-9622 x

Inspector: Mason Lyman

Start Date/Time: 9/2/2014 at 11:08:55 AM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

INDOOR WARM POOL AT FACILITY

SIGNS/RULES OK

LIFEGUARDS ON DUTY

LADDERS/STAIRS OK

ENCLOSURE/FENCES OK

NO ADRUPT EDGES AND POOL HAZARDS

SAFETY EQUIPMENT OK

Free Chlorine (0.8-5.0 ppm):	3.4	Bromine (3.0-8.0 ppm):	Temperature(F):	89
Combined Chlorine (0-.5 ppm):	1.2	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	130	Hardness (175-400 ppm):	280	pH (7.2-7.6):
Inlet Pressure:		Outlet Pressure:		Flow Rate:
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):				0

Comments:

Site Report Generated: 6/23/2017 3:45:18 PM

Person In Charge

Inspection By: Mason Lyman

Historical 11/5/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
TILLAMOOK COUNTY FAMILY YMCA
TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940040 Area: 60
Units: 0
County: 29

TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Phone: (503) 842-9622 x
Inspector: Melissa Kauffman

Start Date/Time: 11/5/2013 at 1:33:03 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION -WARMER POOL

SAFETY EQUIPMENT IS SECURE
LIFE GUARD ON DUTY
SHOWERS AVAILABLE
GOOD SIGNS
LIFE SAVER RING IS READY TO THROW
GOOD SUPERVISION OF SWIMMERS
ENCLOSURES ARE SECURE

Free Chlorine (0.8-5.0 ppm):	2.2	Bromine (3.0-8.0 ppm):	Temperature(F):	89	
Combined Chlorine (0-.5 ppm):	.5	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y	
Total Alkalinity (80-200 ppm):	130	Hardness (175-400 ppm):	260	pH (7.2-7.6):	7.2
Inlet Pressure:		Outlet Pressure:	Flow Rate:	110	

ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):

Comments:

Site Report Generated: 6/23/2017 3:45:18 PM

Historical 5/8/2013

POOL PROGRAM INSPECTION REPORT

**Tillamook Co. Environmental Health PO Box 489 Tillamook, OR 97141
(503) 842-3943**

Owner Name:
TILLAMOOK COUNTY FAMILY YMCA
TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Inspection Type: SEMI
Inspection Result: COMPLD
Establishment #: 2940040 Area: 60
Units: 0
County: 29

TILLAMOOK YMCA POOL 2
610 STILLWELL
TILLAMOOK, OR 97141

Phone: (503) 842-9622 x
Inspector: Melissa Kauffman

Start Date/Time: 5/8/2013 at 12:42:43 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.

THE PURPOSE OF THIS VISIT IS A SEMI ANNUAL INSPECTION OF THE WARMER POOL.

TEMP 90F
PH 7.3
TOTAL CHLORINE 2.4PPM
COMBINED CHLORINE .6 WITH BABIES AND A HIGHER BATHER LOAD DURING INSPECTION
TOTAL ALKALINITY 160PPM
CALCIUM HARDNESS 230PPM

CLARITY IS GREAT
POOL BASIN IS SMOOTH
DECK SURFACE IS SMOOTH AND EASILY CLEANABLE
HANDLE BARS ARE SOLID AND IN PLACE
DOORS LEADING TO THE OUTSIDE ARE LOCKED
SHOWERS ARE PROVIDED
LIFE GUARDS ARE ON DUTY
GOOD RECORD KEEPING
CIRULATION IS GREAT
ALL NECESSARY SAFETY EQUIPMENT PROVIDED

Free Chlorine (0.8-5.0 ppm):	2.4	Bromine (3.0-8.0 ppm):		Temperature(F):	89
Combined Chlorine (0-.5 ppm):	.6	Cyanuric Acid (0-150 ppm):	0	Clarity (Y/N):	Y
Total Alkalinity (80-200 ppm):	160	Hardness (175-400 ppm):	230	pH (7.2-7.6):	7.3
Inlet Pressure:		Outlet Pressure:		Flow Rate:	1.5hrs
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br-):					

Establishment: 2940040

Page 10 of 10

Inspection Type: SEMI

Start Date/Time: 5/8/2013 at 12:42:43

Comments:

Site Report Generated: 6/23/2017 3:45:18 PM

Person In Charge

Inspection By: Melissa Kauffman

Page 10